



104 East 25th St., 10th Fl
 New York, New York 10010
 www.atc-enviro.com
 212.353.8280
 Fax 212.353.8306

September 11, 2002

Mr. Bernard P. Orlan
 Director, Environmental Health & Safety
 New York City Department of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101-4008

**Re: Wipe Samples for Polychlorinated Biphenyls
 DeSoto School (P.S. 130M)
 ATC Project No. 15-19125-0345**

Dear Mr. Orlan:

ATC Associates Inc. (ATC) is pleased to provide this report of the results of wipe samples for polychlorinated biphenyls (PCBs) collected on August 26, 2002, at the referenced locations. The New York City Department of Education (DOE) requested this sampling to evaluate possible contamination inside the school.

Scope of Work

The samples for PCBs were collected using sterile gauze pads and hexane as a solvent. The solvent was provided and samples were analyzed by PSC Analytical Services, Inc. (PSC), an American Industrial Hygiene Association-accredited laboratory in Reading, PA. The PCB analysis was performed using EPA Method 8082B.

Tenzin Namgyal, Industrial Hygienist of ATC's New York City office, collected the samples consistent with generally accepted industrial hygiene practices. There were inherent limitations created by constraints of time, operational and work practice variability, variations in contaminant concentrations, and sampling and analytical accuracy. The results of the sampling represent conditions found on the date the samples were collected.

Results

ATC submitted three (3) samples for PCBs to PSC for analysis. A copy of the analytical laboratory report is provided in the Attachment.

The areas sampled were: the Lobby-Main Entrance, 4th Floor Hallway by Stair C and 5th Floor Hallway by Stair B. The surface area was 100 square centimeters (100cm²).

Mr. Bernard P. Orlan
Wipe Samples for PCBs
DeSoto School/P.S.130M

September 11, 2002

Page 2

ATC Project No. 15-19125-0345

The samples were analyzed for seven PCB compounds with differing percentages of chlorine.

The PCB result for all the samples were *below the reporting limits* (2.0 micrograms/sample) for the analysis.

Currently, the Environmental Protection Agency spill clean-up standard for PCBs on non-porous surfaces is 10 micrograms per 100 square centimeters or less (<10ug/100cm²) as stated in 40 CFR 761.

It is our pleasure to provide these indoor environmental services to the New York City Department of Education. If you have any questions about this report, please call (212) 353-8280, extension 298 or 212.

Sincerely,
ATC ASSOCIATES INC.



Wagdi Abdelshahid
Industrial Hygienist

Reviewed by:



James R. Cohn, CIH, CSP
Regional Manager
Industrial Hygiene Division

Attachment