

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn:

Taylor Environmental Group

Received: 8/20/02 8:00:00 AM

ATC Group #: 8722

Analysis Date: 8/20/02

Fax: (516) 358-1780

Phone:

Project: NYC SCA Project #: M477-15217-29881

Stuyvesant H. S., 9th Floor

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (ASHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-S	5µ		(S/mm ²)	(S/cc)	
9-T1 8722 -1	1305.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
9-T2 8722 -2	1305.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
9-T3 8722 -3	1314.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	
9-T4 8722 -4	1350.50	0.0674	0	None Detected	0	0	0.0042	<14.83	<0.0042	
9-T5 8722 -5	1314.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	
9-T6 8722 -6	1314.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	
9-T7 8722 -7	1314.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	

ROMAN PEYSAKHOV

Analyzed by

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101167-0, NY State ELAP #10679

Attn:

Taylor Environmental Group

Received: 8/20/02

8:00:00 AM

ATC Group #: 8722

Analysis Date: 8/20/02

Fax: (516) 358-1780

Phone:

Project: NYC SCA Project #: M477-15217-29881

Snuyvesant H. S., 9th Floor

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
9-T8 8722 -8	1314.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	
9-T9 8722 -9	1323.00	0.0674	0	None Detected	0	0	0.0043	<14.83	<0.0043	
9-T10 8722 -10	1286.25	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	

ROMAN PEYSAKHOV

Analyzed by



MICHAEL A. GORYCKI, Ph.D.

Approved by

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 2 of 2

CITY_21MC100_003049343