NYC 9/11 Public Portal Document

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-23-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE 07-22-02
DATE RECEIVED: 07-22-02
DATE ANALYZED: 07-22-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu g/ft^2$)	DETECTION LIMIT ($\mu g/ft^2$)
W-01	20559	Rm 638 North Sdie Left Univent (Back Wall)	9.7	9.0
W-02	20559	Rm 639 North Side Right Univent (Back Wall)	<9.0	9.0
W-03	20559	Rm 615B South Side Left Univent (Back Wall)	<9.0	9.0
W-04	20559	Rm 615B South Side Right Univent (Back Wall)	<9.0	9.0
W-05	20559	Rm 636 North Side Right Univent (Back Wall)	<9.0	9.0
W-06	20559	Rm 636 North Side Right Univent (Back Wall)	<9.0	9.0
W-07	20559	Rm 627 South Side Right Univent (Back Wall)	<9.0	9.0
W-08	20559	Rm 627 South Side Left Univent (Back Wall)	<9.0	9.0
W-09	20559	Field Blank	<9.0 µg	9.0 µg
W-10	20559	Field Blank	<9.0 µg	9.0 µg

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 µg
NOTE 2:
HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu g/ft^2$, Window sills 250 $\mu g/ft^2$, Window wells 400 $\mu g/ft^2$, Exterior surfaces 800 $\mu g/ft^2$.
NOTE 3
Blank units are in µg

NYC-WTC_000199502