

Summary of NYC Board of Education Sampling Data for WTC Schools

Prepared by Precision Environmental Inc

Asbestos Samples Summary for Testing Period:09/21/01 to 04/30/02

Name of School	Sample Type	No. of Samples	Results Range	Samples above Guidelines*			Samples <LOD**	
				No.	% Total	Range	No.	% Total
Stuyvesant HS (M477) Testing Period: 09/21/01 to 04/30/02	Bulk Settled Dust	46	ND	0	0.00%	-	46	100.00%
	Soil	0	-	-	-	-	-	-
	Scotch Magic Tape	0	-	-	-	-	-	-
	Air	4,239	<11.12 to 22.24	0	0.00%	-	4228	99.74%
PS 234 Manhattan Testing Period: 10/02/01 to 04/30/02	Bulk Settled Dust	75	ND	0	0.00%	-	75	100.00%
	Soil	13	ND	0	0.00%	-	13	100.00%
	Debris	19	ND	0	0.00%	-	19	100.00%
	Scotch Magic Tape	3	ND	0	0.00%	-	3	100.00%
	Air	1,641	<22.24 to 22.24	0	0.00%	-	1639	99.88%
PS 150 Manhattan Testing Period: 01/22/02 to 04/30/02	Bulk Settled Dust	0	-	-	-	-	-	-
	Soil	0	-	-	-	-	-	-
	Scotch Magic Tape	0	-	-	-	-	-	-
	Air	695	<22.24 to 22.24	0	0.00%	-	693	99.71%
HS For Leadership and Public Service (M894) Testing Period: 12/29/01 to 04/30/02	Bulk Settled Dust	0	-	-	-	-	-	-
	Soil	0	-	-	-	-	-	-
	Scotch Magic Tape	10	ND	0	0.00%	-	10	100.00%
	Micro Vacuum	14	<873	0	0.00%	-	14	100.00%
	Air	1,604	<17.79 to 13345	7	0.44%	956.41 to 13345***	1592	99.25%
HS For Economics and Finance (M833) Testing Period: 01/13/02 to 04/30/02	Bulk Settled Dust	0	-	-	-	-	-	-
	Soil	0	-	-	-	-	-	-
	Scotch Magic Tape	0	-	-	-	-	-	-
	Micro Vacuum	10	<970 to <2909	0	0.00%	-	10	90.00%
	Air	1,130	<14.83 to 22.24	0	0.00%	-	1129	99.91%
PS/IS 89 Manhattan Testing Period: 11/02/01 to 04/30/02	Bulk Settled Dust	38	ND to 0.75%	0	0.00%	-	38	100.00%
	Soil	12	ND to 2.3%	1	8.33%	2.30%	11	91.66%
	Scotch Magic Tape	34	ND	0	0.00%	-	34	100.00%
	Air	1,635	<22.24 to 22.24	0	0.00%	-	1630	99.69%
ALL SCHOOLS TOTAL	Bulk Settled Dust	159	ND	0	0.00%	-	159	100.00%
	Soil	25	ND to 2.3%	1	4.00%	2.30%	24	96.00%
	Scotch Magic Tape	47	ND	0	0.00%	-	47	100.00%
	Micro Vacuum	24	<873 to <2909	0	0.00%	-	24	100.00%
	Air	10,944	<11.12 to 13345	7	0.06%	956.41 to 13345***	9272	84.72%

*Guidelines: USEPA acceptable levels: Bulk < 1%; Air (TEM) < 70 S/mm2

** <LOD : Lower than the limit of detection

*** BOE Believes based on some evidence that these samples were compromised /sabotaged

D= Detected; ND= Non Detected