

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 04-29-02

CLIENT: NYC BOE

PROJECT ADDRESS: I.S.306X/40 West Tremont Ave.,
Bronx, NY 10453

PROJECT NO: 19125-0246

SAMPLED BY: C. Mathew

SAMPLE DATE: 04-28-02

DATE RECEIVED: 04-28-02

DATE ANALYZED: 04-28-02

SAMPLE MEDIA: Dust Wipe Sample

ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
01	9789	Rm 561 (North) East Vent Louver	528.0	19.6
02	9789	Rm 530 (South) East Vent Intake Louver	143.4	19.6
17	9789	Unit Vent CR #418 West	149.2	19.6
18	9789	Unit Vent CR #411 East	259.4	19.6
19	9789	Classroom 322 Unit Vent South	847.2	27.0
20	9789	Classroom 360 Unit Vent South	136.2	19.6
21	9789	Classroom #202 Unit Vent South	1556.8	27.0
22	9789	Classroom #237 East Unit Vent	1817.0	27.0
23	9789	Classroom #115 East Unit Vent	1054.9	27.0
24	9789	Classroom #111 East Unit Vent	1571.7	54.0
29	9789	Blank	<9.0 µg	9.0 µg
30	9789	Blank	<9.0 µg	9.0 µg

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft²,
Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: *HEV*

REPORT PREPARED BY: *[Signature]*

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: *[Signature]*

LABORATORY DIRECTOR: *[Signature]*

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).