

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 04-29-02

CLIENT: NYC BOE

PROJECT ADDRESS: I.S.306X/40 West Tremont Ave.,
Bronx, NY 10453

PROJECT NO: 19125-0246

SAMPLED BY: C. Mathew

SAMPLE DATE: 04-28-02

DATE RECEIVED: 04-28-02

DATE ANALYZED: 04-28-02

SAMPLE MEDIA: Dust Wipe Sample

ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
03	9789	AHV #7 Supply Floor Corridor	127.0	10.3
04	9789	AHV #7 Corridor Return Door	87.0	9.0
05	9789	AHV #6 Supply Atrium Floor	171.0	9.0
06	9789	AHV #6 Atrium Return Floor Lining	18.5	6.8
07	9789	AHV #8 Lockers Supply Floor Liner	67.1	9.0
08	9789	AHV #8 Locker Return Floor Metal	430.6	18.0
09	9789	AHV #10 Auditorium Supply Door	41.2	7.2
10	9789	AHV #10 Auditorium Return Floor Metal	115.2	8.3
11	9789	AHV #10 Corridor Auditorium Supply Floor	33.4	13.5
12	9789	AHV #11 Corridor Return Floor	24.3	8.5
13	9789	AHV #9 GYM Supply Floor	119.5	12.0
14	9789	AHV #9 GYM Return Liner	70.5	9.0
15	9789	AHV #12 Corridor Supply Floor Liner	24.0	9.0
16	9789	AHV #12 Corridor Return Floor Metal	460.5	27.0
25	9789	AHU #3 Library Supply Floor Lining	368.8	9.0

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

26	9789	AHV #3 Library Return	466.7	9.0
27	9789	R-1 Auditorium Supply Lining	130.2	9.0
28	9789	R-1 Auditorium Return Floor	114.6	9.0
31	9789	Blank	<9.0 µg	9.0 µg
32	9789	Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: 9/24

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: M.L.

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).