

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

EMSL

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001

Fax: (516) 358-1780

Phone: 516-358-2955

Project: M477-15217/ SCA/ STUYVESANT H.S. 345 CHAMBERS
ST./ 2ND AND 3RD FLOOR

Customer ID: TAYL50

Customer PO:


Received: 08/06/02 5:54 PM

EMSL Order: 030210733

EMSL Project ID:

Lead in Air by Flame AAS (NIOSH 7082)

Client Sample Description	Lab ID	Analyzed	Volume	Lead Concentration	Notes
1 ROOM 260 AT ENTRANCE TO CORRIDOR	0001		960 L	4.4 µg/m³	
2 ROOM 351 AT ENTRANCE TO CORRIDOR	0002		960 L	<4.2 µg/m³	
3 ROOM 260 AT ENTRANCE TO CORRIDOR	0003		1016 L	<3.9 µg/m³	
4 ROOM 207 AT ENTRANCE TO CORRIDOR	0004		1012 L	<4.0 µg/m³	
5 Field blank	0005		n/a	<4.0 µg/filter	
6 Field blank	0006		n/a	<4.0 µg/filter	


Laboratory Manager
or other approved signatory

Reporting limit is 4 ug/filter. The laboratory is not responsible for data reported in ug/cc which is dependent on volume collected by non-laboratory personnel. This report may not be reproduced except in full, without written approval by EMSL

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581