

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 07-19-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers St., NY

SAMPLED BY: Client

SAMPLE DATE: 07-18-02
DATE RECEIVED: 07-18-02
DATE ANALYZED: 07-18-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
LW-01	20469	Rm 940 North Side Left Univent Rear	<9.0	9.0
LW-02	20469	Rm 940 North Side Right Univent Rear	<9.0	9.0
LW-03	20469	Rm 839 South Side Left Univent Rear	<9.0	9.0
LW-04	20469	Rm 839 South Side Right Univent Rear	<9.0	9.0
LW-05	20469	Rm 837 South Side Left Univent Rear	<9.0	9.0
LW-06	20469	Rm 837 South Side Right Univent Rear	<9.0	9.0
LW-07	20469	Rm 835 South Side Left Univent Rear	<9.0	9.0
LW-08	20469	Rm 835 South Side Right Univent Rear	<9.0	9.0
LW-09	20469	Rm 833 South Side Left Univent Rear	<9.0	9.0
LW-10	20469	Rm 833 South Side Right Univent Rear	<9.0	9.0
LW-11	20469	Rm 829 South Side Left Univent Rear	<9.0	9.0
LW-12	20469	Rm 829 South Side Right Univent Rear	<9.0	9.0
LW-13	20469	Field Blank	<9.0 µg	9.0 µg
LW-14	20469	Field Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

ATC ASSOCIATES, INC

104 E 25th Street, 10th Floor

New York, NY 10010

Tel. 212-353-8280

Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: _____



REPORT PREPARED BY: _____



ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: _____



LABORATORY DIRECTOR: _____



ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).