

ATC ASSOCIATES, INC**104 E 25th Street, 10th Floor****New York, NY 10010****Tel. 212-353-8280****Fax 212-353-8306**

REPORT DATE: 07-30-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 07-29-02
DATE RECEIVED: 07-29-02
DATE ANALYZED: 07-29-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
07	20744	Rm 1001 Floor W2 19-7	<9.0	9.0
08	20744	Rm 1001 Desk	<9.0	9.0
09	20744	Rm 1002 Floor W-2 8-1	<9.0	9.0
10	20744	Rm 1002 Shelf	<9.0	9.0
11	20744	Rm 1003 Floor W-4 2-1	<9.0	9.0
12	20744	Rm 1003 Floor Shelf	<9.0	9.0
13	20744	Rm 1004 Floor W-2 5-1	<9.0	9.0
14	20744	Rm 1004 Teachers Desk	<9.0	9.0
15	20744	Rm 1005 Floor W-2 3-1	<9.0	9.0
16	20744	Rm 1005 Shelf	<9.0	9.0
17	20744	Rm 1006 Floor W-8 8-8	<9.0	9.0
18	20744	Rm 1006 Table	<9.0	9.0
19	20744	Rm 1007 Floor W4 4-2	<9.0	9.0
20	20744	Rm 1007 Desk	<9.0	9.0
21	20744	Rm 1039A Floor W2 3-3	<9.0	9.0

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

22	20744	Rm 1039A Shelf	<9.0	9.0
23	20744	Rm 1039 Floor W1 1-1	<9.0	9.0
24	20744	Rm 1039 Table	<9.0	9.0
FB-3	20744	Field Blank	<9.0 µg	9.0 µg
FB-4	20744	Field Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft²,
Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: RD

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: [Signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).