

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-05-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 08-03-02
DATE RECEIVED: 08-03-02
DATE ANALYZED: 08-03-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
W-01	20892	Rm 911 Teacher Table Lower End	<9.0	9.0
W-02	20892	Rm 911 Floor by the TV Set	<9.0	9.0
W-03	20892	Rm 913 Table by Emergency Shower	<9.0	9.0
W-04	20892	Rm 913 Floor SE Corner	<9.0	9.0
W-05	20892	Rm 925 Teacher Desk	<9.0	9.0
W-06	20892	Rm 925 Floor by SW Side Window	<9.0	9.0
W-07	20892	Rm 925B Table by the Entrance	<9.0	9.0
W-08	20892	Rm 925B Floor by the Entrance	<9.0	9.0
W-09	20892	Rm C923 Floor by the Entrance	<9.0	9.0
W-10	20892	Rm C932 Floor by the Entrance	<9.0	9.0
W-11	20892	Rm 909 Table Computer Table	<9.0	9.0
W-12	20892	Rm 909 Floor by the Entrance	<9.0	9.0
W-13	20892	Corridor Floor by Rm 939	<9.0	9.0
W-14	20892	Corridor Floor by Rm C921	<9.0	9.0
W-15	20892	Corridor Floor by Rm 905	<9.0	9.0
W-16	20892	Field Blank	<9.0 μg	9.0 μg
W-17	20892	Field Blank	<9.0 μg	9.0 μg

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$,
Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: EL

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: [Signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).