

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com



Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001

Fax: (516) 358-1780 Phone: 516-358-2955

Project: M477-15217/29881 / NYC-SCA / STUYVESANT H.S

Customer ID: TAYL50

Customer PO:


Received: 08/17/02 4:28 PM

EMSL Order: 030211415

EMSL Project ID:

Lead in Wipes by Flame AAS (SW 846, 7420)

<i>Client Sample Description</i>	<i>Lab ID</i>	<i>Analyzed</i>	<i>Area Sampled</i>	<i>Lead Concentration</i>	<i>Notes</i>
LW-01 ROOM #336-D / TOP OF CABINET	0001	8/17/2002	144 in ²	<10.0 µg/ft ²	
LW-02 ROOM #336-D / FLOOR BY ENTRANCE	0002	8/17/2002	144 in ²	<10.0 µg/ft ²	
FB 1 Field blank	0003	8/17/2002	n/a	<10.0 µg/wipe	
FB 2 Field blank	0004	8/17/2002	n/a	<10.0 µg/wipe	


Laboratory Manager
or other approved signatory

Reporting limit is 10 ug/wipe

ACCREDITATIONS: AIHA Environmental Lead Laboratory Approval Program #102581