

ATC ASSOCIATES, INC**104 E 25th Street, 10th Floor****New York, NY 10010****Tel. 212-353-8280****Fax 212-353-8306**

REPORT DATE: 08-26-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217-29881

SAMPLED BY: Client

SAMPLE DATE: 08-26-02
DATE RECEIVED: 08-26-02
DATE ANALYZED: 08-26-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft ²)	DETECTION LIMIT (µg/ft ²)
LW-1	21474	Basement Rm C039 Floor Center of Room	9.7	9.0
LW-2	21474	Basement Rm C039 SW Shelf	<9.0	9.0
LW-3	21474	Basement Rm C037 Floor at Center	<9.0	9.0
LW-4	21474	Basement Rm C037 Table Top	<9.0	9.0
LW-5	21474	Basement Rm C040 Floor 10' of Entrance	<9.0	9.0
LW-6	21474	Basement Rm C040 Desk Top West of Ent.	<9.0	9.0
LW-7	21474	Basement Rm C036 Floor 4' of Entrance	<9.0	9.0
LW-8	21474	Basement Rm 033 Floor at Center	11.4	9.0
LW-9	21474	Basement Rm 033 Top of Archive Box	<9.0	9.0
LW-10	21474	Basement Rm C030 Floor West Side of North Tank	<9.0	9.0
LW-11	21474	Basement Rm C030 Top of Small Tank	<9.0	9.0
LW-12	21474	Basement Rm C031 Floor 5' of Entrance	<9.0	9.0
LW-13	21474	Basement Rm C031 Shelf NE Side of Rm	<9.0	9.0

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

LW-14	21474	Basement Rm C029 Floor SE Side	14.4	9.0
LW-15	21474	Basement Rm C029 Top of Black File Cabinet	<9.0	9.0
LW-16	21474	Basement Rm C027 Floor Center of Rm	11.0	9.0
LW-17	21474	Basement Rm C027 Top of Locker #92	7.6	9.0
LW-18	21474	Basement Rm C025 Floor 10' of Entrance	100.8	9.0
LW-19	21474	Basement Rm C025 Chair Seat	9.1	9.0
LW-20	21474	Basement Rm C022 Floor 3' of Entrance	<9.0	9.0
LW-21	21474	Basement Rm C022 Shelf (Center)	<9.0	9.0
FBL-1	21474	Field Blank	<9.0 µg	9.0 µg
FBL-2	21474	Field Blank	<9.0 µg	9.0 µg
FBL-3	21474	Field Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft², Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².

NOTE 3:

Blank units are in µg

CERTIFICATION AND SIGNATURESANALYSIS PERFORMED BY: ILREPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]LABORATORY DIRECTOR: [Signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

CITY_21MC100_003266559