

TAYLOR ENVIRONMENTAL GROUP

DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

TECHNICIAN <i>G. Gordon</i>		CLIENT <i>NYC SCA</i>		SITE ADDRESS <i>STUYVESANT H.S. CAMBORG ST, NY NY</i>				DATE SUBMITTED <i>8/25/02</i>			
DATE SAMPLED <i>08-24-02</i>		CONTACT <i>AMIT SAHAI</i>		WORK AREA <i>2nd Floor</i>				DATE LOGGED			
ROTOMETER NO. <i>756-L18</i>		PROJECT NO. <i>M477-15217-29552</i>		PROJECT MANAGER <i>George Nyc</i>				DATE APPROVED / SIGNATURE <i>[Signature]</i>			

SAMPLE & PUMP #	LABORATORY NO.	SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE	FLOW ON/OFF	TIME ON	TIME OFF	DURATION MINUTES	FLOW (AVERAGE)	LITERS	FIELDS	FIBERS	F/MM ²	F/CB
2-L1		IWA ☒ 2nd floor corridor by OWA ☐ main elevator	4.0	1945	2400	255	4.0	1020				11.5
2-L2		IWA ☒ 2nd floor corridor OWA ☐ of rm. 233	4.0	1946	0001	255	4.0	1020				11.5
2-L3		IWA ☒ 2nd floor corridor OWA ☐ of rm. 231	4.0	1948	0003	255	4.0	1020				11.5
FB-1		IWA ☐ OWA ☐ F/BUANE-1	/									11.5
FB-2		IWA ☐ OWA ☐ F/BUANE-2	/									11.5
		IWA ☐ OWA ☐	/									
		IWA ☐ OWA ☐	/									
		IWA ☐ OWA ☐	/									
		IWA ☐ OWA ☐	/									
		IWA ☐ OWA ☐	/									
		IWA ☐ OWA ☐	/									
		IWA ☐ OWA ☐	/									
		IWA ☐ OWA ☐	/									
		IWA ☐ OWA ☐	/									
		IWA ☐ OWA ☐	/									

RELINQUISHED TO TEG DROP BOX (SIGNATURE) <i>[Signature]</i>	DATE <i>8-25-02</i>	TIME <i>00:10</i>	RECEIVED FROM TEG DROP BOX (SIGNATURE) <i>ATC</i>	DATE	TIME	CIRCLE PCM TEM PRE DURING POST BGRD OSHA OTHER <i>[Signature]</i>
RELINQUISHED BY (SIGNATURE) <i>[Signature]</i>	DATE <i>8/25/02</i>	TIME <i>01:00</i>	RECEIVED BY (SIGNATURE) <i>ATC</i>	DATE <i>08/25/02</i>	TIME <i>01:20</i>	
ANALYST: (SIGNATURE) <i>[Signature]</i>	DATE <i>8-25-02</i>	TIME <i>3:00 AM</i>	COMMENTS <i>SHAZAT</i>	212-406-2535 FAX 516-358-1780 LOT # FILTER MANUFACTURER		

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

(ATC)

CITY_21MC100_011274071

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-26-02
CLIENT: Taylor Environmental Group, Inc.
PROJECT NAME: SCA/Stuyvesant HS
2nd Floor
PROJECT NUMBER: M477-15217/29881
SAMPLED BY: Client
SAMPLE DATE 08-25-02
DATE RECEIVED: 08-25-02
DATE ANALYZED: 08-25-02
SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{m}^3$)	DETECTION LIMIT ($\mu\text{g}/\text{m}^3$)
2-L1	21468	2nd Floor Corridor by Main Elevator	<1.5	1.5
2-L2	21468	2nd Floor Corridor O/S Rm 233	<1.5	1.5
2-L3	21468	2nd Floor Corridor O/S Rm 271	<1.5	1.5
FB1	21468	Field Blank	<1.5 μg	1.5 μg
FB2	21468	Field Blank	<1.5 μg	1.5 μg

NOTE 1:**THE REPORTING LIMIT (RL) IS 3.0 μg** **NOTE 2:**At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu\text{g}/\text{m}^3$ and a permissible exposure level (PEL) of 50 $\mu\text{g}/\text{m}^3$ for personal samples.**NOTE 3:**Blank units are in μg