TAYLOR ENVIRONMENTAL GROUP — DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD — PAGE 1 OF 2

TECHNICIAN: G. Pettranelli / Teresa	CLIENT: AMNYCSCA	SITE ADDRESS: Stuyvesant H.S., NY, NY	DATE SUBMITTED: 8.20.02
DATE SAMPLED: 8-20-02	CONTACT: Hamid Savoy	WORK AREA: Various	DATE LOGGED:
ROTOMETER NO.: TEG-147	PROJECT NO.: M477-15217-29882	PROJECT MANAGER: G. Taylor	DATE APPROVED / SIGNATURE:

SAMPLE & PUMP #	LABORATORY NO.	SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE	FLOW ON/OFF	TIME ON	TIME OFF	DURATION MINUTES	FLOW (AVERAGE)	LITERS	FIELDS	FIBERS	F/MM²	F/CC
S-1		IWA ☑ OWA ☐ Room 105 I/S Tont	8/7	1540	18.30	170	7.5	1275	0			
S-2		IWA ☑ OWA ☐ Room 105 "	8/8	1541	18.31	170	8	1360				
S-3		IWA ☑ OWA ☐ Room 105 "	8/8	1542	18.32	170	8	1360				
S-4		IWA ☑ OWA ☐ Room 105 "	8/7.5	1543	18.33	170	7.75	1318				
S-5		IWA ☑ OWA ☐ Room 105 "	8/8	1544	18.34	170	8	1360				
AF-~~1~~ 6		IWA ☑ OWA ☐ Auditorium - Floor I/S Tont	8/8	1551	18.41	170	8	1360				
AF-~~2~~ 7		IWA ☑ OWA ☐ Auditorium - Floor I/S Tont	10/9	1552	18.42	170	9.5	1615				
AF-~~3~~ 8		IWA ☑ OWA ☐ Auditorium - Floor I/S Tont	8/8	1553	18.43	170	8	1360				
AF-~~4~~ 9		IWA ☑ OWA ☐ Auditorium Floor I/S Tont	8/7.5	1554	18.44	170	7.75	1318	0302	11524		
AF-~~5~~ 10		IWA ☑ OWA ☐ Auditorium Floor I/S Tont	8/7	1555	18.45	170	7.5	1275	0302	11536		
AS-11		IWA ☑ OWA ☐ Auditorium - Soats I/S - Tont	8/8	1608	18.58	170	8	1360				
AS-12		IWA ☑ OWA ☐ Auditorium - Soats I/S - Tont	8/7.5	1609	18.59	170	7.75	1318				
AS-13		IWA ☑ OWA ☐ Auditorium - Soats I/S - Tont	8/8	1610	19.00	170	8	1360				

02 AUG 20 PM 7:37

EMSL MANAGEMENT RECEIVED

RELINQUISHED TO TEG DROP BOX (SIGNATURE)	DATE	TIME	RECEIVED FROM TEG DROP BOX (SIGNATURE)	DATE	TIME
	8-20-02		[signature]	8/20/02	7:40 PM
RELINQUISHED BY: (SIGNATURE) [signature]	DATE 8.20.02	TIME 19.40	RECEIVED BY: (SIGNATURE) Teresa Michalczuk	DATE	TIME
ANALYST: (SIGNATURE) [signature]	DATE 8/20/02	TIME 11:40 PM	COMMENTS: Chrysotile Analyze - 1 → 20		

CIRCLE: PCM / TEM / BGRD / PRE / DURING / POST / OSHA / OTHER: AMBIENT

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

20 @ 6hr

EMSL

CITY_21MC100_011274090

TAYLOR ENVIRONMENTAL GROUP

DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 2 OF 2

TECHNICIAN: G. Petranek / Torres	CLIENT: NYC-SCA	SITE ADDRESS: Stuyvesant H.S, N.Y. NY	DATE SUBMITTED: 8/20/02
DATE SAMPLED: 8-20-02	CONTACT: Hamid Savon	WORK AREA: Various	DATE LOGGED:
ROTOMETER NO.: TEG-147	PROJECT NO.: M477-15217-29882	PROJECT MANAGER: G. Taylor	DATE APPROVED / SIGNATURE:

SAMPLE & PUMP #	LABORATORY NO.	SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE	FLOW ON/OFF	TIME ON	TIME OFF	DURATION MINUTES	FLOW (AVERAGE)	LITERS	FIELDS	FIBERS	F/MM²	F/CC
AS-14		IWA ☑ OWA ☐ Auditorium - Seats I/S - Tent	10/9	1611	19.01	170	9.5	1615				
AS-15		IWA ☑ OWA ☐ Auditorium - Seats I/S Tent	8/8	1612	19.02	170	8	1360				
O-16		IWA ☐ OWA ☑ 1st FL Corridor O/S Rm 101/103	8/7	1621	19.11	170	7.5	1275				
O-17		IWA ☐ OWA ☑ 1st FL Corridor O/S Rm 107	8/7	1622	19.12	170	7.5	1275				
O-18		IWA ☐ OWA ☑ 1st FL Corridor / Lobby @ Public Phones	8/8	1623	19.13	170	8	1360	030211524			
O-19		IWA ☐ OWA ☑ 1st FL Corridor O/S Room 100-H	8/7.5	1624	19.14	170	7.75	1318				
O-20		IWA ☐ OWA ☑ 1st FL Corridor @ Locker 1-31	8/8	1625	19.15	170	8	1360				
FB-1		IWA ☐ OWA ☐ F/Blank-1										
FB-2		IWA ☐ OWA ☐ F/Blank-2										
SB-1		IWA ☐ OWA ☐ S/Blank-1										
		IWA ☐ OWA ☐										
		IWA ☐ OWA ☐							030211536			
		IWA ☐ OWA ☐										

02 AUG 20 PM 7:37

EMSL MANHATTAN RECEIVED

RELINQUISHED TO TEG DROP BOX (SIGNATURE)	DATE	TIME	RECEIVED FROM TEG DROP BOX (SIGNATURE)	DATE	TIME
	8-20-02		Elsi Quispe	8/20/2	7:40 PM
RELINQUISHED BY: (SIGNATURE) Teresa Lafu	DATE 8.20.02	TIME 19.40	RECEIVED BY: (SIGNATURE) Teresa Michalczuk	DATE	TIME
ANALYST: (SIGNATURE) C.W. / F. Cross	DATE 8/20/02	TIME 11:49 PM	COMMENTS 6 HR TAT Analyze T1 → T20		

CIRCLE: PCM TEM BGRD PRE DURING POST OSHA OTHER Ambient

LOT #

FILTER MANUFACTURER

WHITE: Office Copy YELLOW: Lab Copy PINK: Samples ORANGE: Site Copy

EMSL

CITY_21MC100_011274091

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: **M477-15217-29881 / NYCSCA / Stuyvesant HS, NY, NY / Various**

Customer ID: TAYL50
Customer PO:
Received: 08/20/02 7:37 PM
EMSL Order: 030211524
EMSL Project ID:
Analysis Date: 8/20/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures ≥ 0.5µ < 5	# Structures ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
S-1 *030211524-0001*	1275.00	0.0625	2	None Detected			0.0048	<16.00	<0.0048	
S-2 *030211524-0002*	1360.00	0.0625	0	None Detected			0.0045	<16.00	<0.0045	
S-3 *030211524-0003*	1360.00	0.0625	0	None Detected			0.0045	<16.00	<0.0045	
S-4 *030211524-0004*	1318.00	0.0625	0	None Detected			0.0047	<16.00	<0.0047	
S-5 *030211524-0005*	1360.00	0.0625	1	None Detected			0.0045	<16.00	<0.0045	
AF-6 *030211524-0006*	1360.00	0.0625	3	None Detected			0.0045	<16.00	<0.0045	
AF-7 *030211524-0007*	1615.00	0.0500	1	Chrysotile	2	0	0.0048	40	0.0095	
AF-8 *030211524-0008*	1360.00	0.0625	0	None Detected			0.0045	<16.00	<0.0045	
AF-9 *030211524-0009*	1318.00	0.0625	5	None Detected			0.0047	<16.00	<0.0047	
AF-10 *030211524-0010*	1275.00	0.0625	0	Chrysotile	6	0	0.0048	96	0.0290	
AS-11 *030211524-0011*	1360.00	0.0625	2	None Detected			0.0045	<16.00	<0.0045	

Analyst(s)
George Williams (12)
Rey Cross (8)

Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.
Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

CITY_21MC100_011274092

NYC-WTC_000200162

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn: Taylor Environmental Group, Inc.
Floral Park Corporate Center
130 Jericho Tpke.
Floral Park, NY 11001
Fax: (516) 358-1780 Phone: 516-358-2955
Project: **M477-15217-29881 / NYCSCA / Stuyvesant HS, NY, NY / Various**

Customer ID: TAYL50
Customer PO:
Received: 08/20/02 7:37 PM
EMSL Order: 030211524
EMSL Project ID:
Analysis Date: 8/20/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures ≥0.5μ < 5	# Structures ≥ 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
AS-12 *030211524-0012*	1318.00	0.0625	0	None Detected			0.0047	**<16.00**	**<0.0047**	
AS-13 *030211524-0013*	1360.00	0.0625	0	None Detected			0.0045	**<16.00**	**<0.0045**	
AS-14 *030211524-0014*	1615.00	0.0625	0	None Detected			0.0038	**<16.00**	**<0.0038**	
AS-15 *030211524-0015*	1360.00	0.0625	6	None Detected			0.0045	**<16.00**	**<0.0045**	
O-16 *030211524-0016*	1275.00	0.0625	0	None Detected			0.0048	**<16.00**	**<0.0048**	
O-17 *030211524-0017*	1275.00	0.0625	4	None Detected			0.0048	**<16.00**	**<0.0048**	
O-18 *030211524-0018*	1360.00	0.0625	1	None Detected			0.0045	**<16.00**	**<0.0045**	
O-19 *030211524-0019*	1318.00	0.0625	0	None Detected			0.0047	**<16.00**	**<0.0047**	
O-20 *030211524-0020*	1360.00	0.0625	0	None Detected			0.0045	**<16.00**	**<0.0045**	

Analyst(s)
George Williams (12)
Rey Cross (8)

José Arriaga
Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.
Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

CITY_21MC100_011274093
NYC-WTC_000200163

NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

Attn:	Taylor Environmental Group, Inc. Floral Park Corporate Center 130 Jericho Tpke. Floral Park, NY 11001	Customer ID:	TAYL50
		Customer PO:	
		Received:	08/21/02 7:30 AM
Fax:	(516) 358-1780 Phone: 516-358-2955	EMSL Order:	030211536
Project:	**M477-15217-29881 / NYC SCA / STUYVESANT H.S. NY, NY / VARIOUS**	EMSL Project ID:	
		Analysis Date:	8/21/2002

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures ≥ 0.5µ < 5	# Structures ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
AF-10	1275.00	0.0625	0	Chrysotile	3	0	0.0048	**48**	**0.0145**	
030211536-0001										

QC Sample

Analyst(s)

Bob Georgans (1)

Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

CITY_21MC100_011274094

NYC-WTC_000200164