

TAYLOR / ENVIRONMENTAL GROUP

DAILY MONITORING SHEET AND CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

TECHNICIAN <i>B. Gordon</i>		CLIENT <i>NTE-SCA</i>		SITE ADDRESS <i>345 Chambers St. N.Y.C.</i>				DATE SUBMITTED <i>8-29-2</i>			
DATE SAMPLED <i>8-28-2</i>		CONTACT <i>Mamud Saouj</i>		WORK AREA <i>Thru elevators on 3rd floor</i>				DATE LOGGED			
ROTOMETER NO. <i>TEG L-18</i>		PROJECT NO. <i>1477-15217-29881</i>		PROJECT MANAGER <i>G. Taylor</i>				DATE APPROVED / SIGNATURE			

SAMPLE & PUMP #	LABORATORY NO.	SAMPLE LOCATION, AREA & HEIGHT AND/OR EMPLOYEE	FLOW ON/OFF	TIME ON	TIME OFF	DURATION MINUTES	FLOW (AVERAGE)	LITERS	FIELDS	FIBERS	F/MM ²	E/CG
<i>L01</i>		<i>IWA ☒ INSIDE RIGHT PASSENGER ELEVATOR LOCATED AT 3rd FIR.</i>	<i>4.0</i>	<i>2250</i>	<i>3:10</i>	<i>260</i>	<i>4.0</i>	<i>1090</i>				<i>4.4</i>
<i>L02</i>		<i>IWA ☒ INSIDE SERVICE ELEVATOR LOCATED AT 3rd FIR.</i>	<i>4.0</i>	<i>2251</i>	<i>3:11</i>	<i>260</i>	<i>4.0</i>	<i>1040</i>				<i>4.4</i>
<i>L03</i>		<i>IWA ☒ INSIDE POOL ELEVATOR LOCATED AT SUB-GROUND LEVEL.</i>	<i>4.0</i>	<i>2300</i>	<i>3:20</i>	<i>260</i>	<i>4.0</i>	<i>1090</i>				<i>4.4</i>
<i>F/B-1</i>		<i>IWA ☐ F/B-1</i>										<i>4.5</i>
<i>F/B-2</i>		<i>IWA ☐ F/B-2</i>										<i>4.5</i>
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										
		<i>IWA ☐</i>										

RELINQUISHED TO TEG DROP BOX (SIGNATURE) <i>[Signature]</i>	DATE <i>8-29-2</i>	TIME <i>03:30</i>	RECEIVED FROM TEG DROP BOX (SIGNATURE) <i>[Signature]</i>	DATE <i>8-29-2</i>	TIME <i>04:10</i>	CIRCLE PCM TEM BGRO PRE DURING POST OSHA OTHER <i>Lead</i>
RELINQUISHED BY (SIGNATURE) <i>[Signature]</i>	DATE <i>8-29-2</i>	TIME <i>4:00</i>	RECEIVED BY (SIGNATURE) <i>R. Broudina</i>	DATE <i>8-29-2</i>	TIME <i>04:10</i>	
ANALYST (SIGNATURE) <i>R. Broudina</i>	DATE <i>8-29-2</i>	TIME <i>06:30</i>	COMMENTS <i>3M TAT</i>	FILTER MANUFACTURER <i>Form 1-212-406-2535</i> <i>1-516-358-1780</i>		

WHITE: Office Copy

YELLOW: Lab Copy

PINK: Samples

ORANGE: Site Copy

CITY_21MC100_011274123

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 08-29-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
Stuyvesant H. S. - Elevators on 3rd Floor Location

PROJECT NUMBER: M477-15217/29881

SAMPLED BY: Client

SAMPLE DATE: 08-29-02
DATE RECEIVED: 08-29-02
DATE ANALYZED: 08-29-02

SAMPLE MEDIA: Air Samples
ANALYSIS REQUIRED: Method NIOSH 7082

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{m}^3$)	DETECTION LIMIT ($\mu\text{g}/\text{m}^3$)
L01	21610	Inside Right Passenger Elevator Located at 3rd Floor	<1.4	1.4
L02	21610	Inside Service Elevator Located at 3rd Floor	<1.4	1.4
L03	21610	Inside Pool Elevator Located at Sub-Ground Level	<1.4	1.4
FB1	21610	Field Blank	<1.5 μg	1.5 μg
FB2	21610	Field Blank	<1.5 μg	1.5 μg

NOTE 1:**THE REPORTING LIMIT (RL) IS 3.0 μg** **NOTE 2:**

At the present time there are no regulatory levels or requirements for indoor airborne lead in area samples. However, OSHA has established an action level of 30 $\mu\text{g}/\text{m}^3$ and a permissible exposure level (PEL) of 50 $\mu\text{g}/\text{m}^3$ for personal samples.

NOTE 3:Blank units are in μg

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: AD

REPORT PREPARED BY: [Signature]

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: [Signature]

LABORATORY DIRECTOR: [Signature]

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).