

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 3/31/02 7:00:00 PM
 ATC Group #: 7285
 Analysis Date: 3/31/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5μ-5	5μ		(S/mm ²)	(S/cc)	
01 7285 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
02 7285 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
03 7285 -3	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
04 7285 -4	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
05 7285 -5	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
06 7285 -6	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
07 7285 -7	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY

Received: 3/31/02

7:00:00 PM

ATC Group #: 7285

Analysis Date: 3/31/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5µ	5µ		(S/mm ²)	(S/cc)	
08 7285 -8	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
09 7285 -9	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
10 7285 -10	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
11 7285 -11	1880.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
12 7285 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
13 7285 -13	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
14 7285 -14	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
15 7285 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
16 7285 -16	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879