

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/10/02 8:00:00 PM
 ATC Group #: 8035
 Analysis Date: 6/10/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY
 Playground, Roof All Floors Hallway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
01 8035 -1	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
02 8035 -2	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
03 8035 -3	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
04 8035 -4	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 8035 -5	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 8035 -6	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 8035 -7	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 6/10/02 8:00:00 PM
 ATC Group #: 8035
 Analysis Date: 6/10/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: PS 89M 201 Warren Street, New York, NY
 Playground, Roof All Floors Hallway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
08 8035 -8	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 8035 -9	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 8035 -10	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 8035 -11	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
12 8035 -12	1805.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 8035 -13	1852.50	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
14 8035 -14	1852.50	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
15 8035 -15	1805.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 8035 -16	1805.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879