NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	1	**Grid Opening Size:**	0.01124
Client Sample #:	01	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	E09	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO		Structure No	Structure Type				Length		ID of Structure N or √				EDS (Nonadb Elements)
No	Coord		F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	
1	W1	NSD											
E09 2	P1	— C											
3	N3	— C											
4S	F3	— C											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber

B = Bundle (<3 fibers <1 fiber diameter apart

C = Cluster (>3 Intersections)

M = Matrix

NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES

Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000201030

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	2	**Grid Opening Size:**	0.01124
Client Sample #:	02	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	5CR	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO.	Structure	Structure Type				Length		ID of Structure N or √				EDS
No Coord	No	F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	(Nonadb Elements)
5C 1 KL1	1050											
2 R1	—											
— 3 JC	—											
5R 4 Q2	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000201031

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	3	**Grid Opening Size:**	0.01124
Client Sample #:	03	**Area Examined:**	0.04496 mm²
GRID BOX:	1137	**Magnification:**	20,000
GRID ID:	S-02	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	CE	NSO											
2	AE	—											
3	DF	—											
4	CF	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000201032

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	4	**Grid Opening Size:**	0.01124
Client Sample #:	04	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	5806	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	F3	NSD											
2	K3	—											
3	P1	—											
4	U1	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000201033

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	5	**Grid Opening Size:**	0.01124
Client Sample #:	05	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	6440	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO.		Structure	Structure Type				Length		ID of Structure N or √				EDS
No	Coord	No	F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	(Nonadb Elements)
1	92	1											
2	62	—											
3	61	—											
60 4	41	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000201034

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	6	**Grid Opening Size:**	0.01124
Client Sample #:	06	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	6AS	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO		Structure No	Structure Type				Length		ID of Structure N or √				EDS (Nonadb Elements)
No	Coord		F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	
1	K1	NSD											
6A 2	R1	—											
3	S3	—											
6S 4	J3	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000201035

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	7	**Grid Opening Size:**	0.01124
Client Sample #:	07	**Area Examined:**	0.04496 mm²
GRID BOX:	1137	**Magnification:**	20,000
GRID ID:	7cc	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	Length >=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	82	NSD											
2	82	— "											
3	81	— "											
4	8F	— "											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance

<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000201036

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	8	**Grid Opening Size:**	0.01124
Client Sample #:	08	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	7BL	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO		Structure No	Structure Type				Length		ID of Structure N or √				EDS (Nonadb Elements)
No	Coord		F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	
1	R1	NSD											
2	R1	—											
3	E1	—											
4	J1	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000201037

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	9	**Grid Opening Size:**	0.01124
Client Sample #:	09	**Area Examined:**	0.04496 mm²
GRID BOX:	1167	**Magnification:**	20,000
GRID ID:	2 T 8 C	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO		Structure No	Structure Type				Length		ID of Structure N or √				EDS (Nonadb Elements)
No	Coord		F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	
				Filter missing									

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1840
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	10	**Grid Opening Size:**	0.01124
Client Sample #:	10	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	Blue	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	Length >=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	J2	NSD											
2	Q2	—											
3	O1	—											
4	E1	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber

B = Bundle (<3 fibers <1 fiber diameter apart

C = Cluster (>3 Intersections)

M = Matrix

NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES

Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1848
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	11	**Grid Opening Size:**	0.01124
Client Sample #:	11	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	8485	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO. No	Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	07	NSO											
2	07	-"											
3	07	-"											
4	07	-"											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS *spectrum conforming* to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% *holes or opaque areas*

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1805
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	12	**Grid Opening Size:**	0.01124
Client Sample #:	12	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	9CC	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	J3	NSO											
2	E3	—											
3	J01	—											
4	E1	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000201041

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1805
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	13	**Grid Opening Size:**	0.01124
Client Sample #:	13	**Area Examined:**	0.04496 mm²
GRID BOX:	1137	**Magnification:**	20,000
GRID ID:	9AK	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO. No	Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
9P	1 X 9	NSD											
	2 9 8	— " —											
	3 V 1	— " —											
9R	4 2 1	— " —											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded
<10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1805
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	14	**Grid Opening Size:**	0.01124
Client Sample #:	14	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	9F10A	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO.		Structure No	Structure Type				Length		ID of Structure N or √				EDS (Nonadb Elements)
No	Coord		F	B	C	M	>=05 µ <5µ	>=5µ	Chrys	Amphibole	Nonasb	Ambig/ND	
1	3E	NSD											
2	EE	—											
3	E1	—											
4	P1	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber

B = Bundle (<3 fibers <1 fiber diameter apart

C = Cluster (>3 Intersections)

M = Matrix

NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES

Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1805
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	15	**Grid Opening Size:**	0.01124
Client Sample #:	15	**Area Examined:**	0.04496 mm²
GRID BOX:	1137	**Magnification:**	20,000
GRID ID:	2040	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	Length >=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	C1	NSD											
2	H1	—											
3	D1	—											
4	E1	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:

<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					

NYC-WTC_000201044

NYC 9/11 Public Portal Document

TEM Asbestos (air) Count Sheet

Client Name:	NYC BOE	**Volume (liters):**	1805
Lab Group #:	7823	**Filter Type / Filter Area:**	MCE 385 mm²
Lab Sample #:	16	**Grid Opening Size:**	0.01124
Client Sample #:	16	**Area Examined:**	0.04496 mm²
GRID BOX:	1157	**Magnification:**	20,000
GRID ID:	1085	**Accelerating Voltage:**	100 KeV
# Grid Openings:	4	**Analysis Date:**	5/21/02

Analysis Performed By: MARK PEYSAKHOV

GO. No	GO. Coord	Structure No	Structure Type F	B	C	M	Length >=05 µ <5µ	>=5µ	ID of Structure N or √ Chrys	Amphibole	Nonasb	Ambig/ND	EDS (Nonadb Elements)
1	83	NSD											
2	143	—											
3	V1	—											
4	P1	—											

Struct = > 0.5µ > 5:1 Aspect Ratio

√= Positive diffraction pattern properties conforming to laboratory identification criteria observed

√= EDS spectrum conforming to laboratory identification criteria observed

F = Single Fiber
B = Bundle (<3 fibers <1 fiber diameter apart
C = Cluster (>3 Intersections)
M = Matrix
NSD = No Structures Detected

Grid acceptance:
<50% undissolved filter, overlapped or folded <10% particulate coverage >50% coverage ate least 20 unfolded or overlapped grid squares <5% holes or opaque areas

AMPHIBOLES
Amosite
Crocidolite
Anthophyllite
Tremolite
Actinolite

Totals

	F	B	C	M	>5µ
Chrysotile					
Amphibole					
Ambiguous					
Non-Asbestos					
Non-Identified					