

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY

Received: 4/21/02

7:00:00 PM

ATC Group #: 7494

Analysis Date: 4/21/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
01 7494 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
02 7494 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
03 7494 -3	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
04 7494 -4	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
05 7494 -5	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
06 7494 -6	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
07 7494 -7	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLWTEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 4/21/02 7:00:00 PM
ATC Group #: 7494
Analysis Date: 4/21/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: PS 89M 201 Warren Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5 μ -5 5 μ		Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)		Notes
08 7494 -8	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
09 7494 -9	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
10 7494 -10	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
11 7494 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
12 7494 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
13 7494 -13	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
14 7494 -14	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
15 7494 -15	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
16 7494 -16	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. The lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879