


ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 3TIME 15:30LOCATION P589 M DATE 1/28/02 PROJECT NO. 19125-297

| Location                            | Occup. | Temperature<br>(°F)                | Relative<br>Humidity (%) | Carbon Dioxide<br>(ppm)    | Carbon Monoxide<br>(ppm) | Respirable<br>Particulates(ug/m <sup>3</sup> ) | TVOCs<br>(ppm) |
|-------------------------------------|--------|------------------------------------|--------------------------|----------------------------|--------------------------|------------------------------------------------|----------------|
| Playground North                    |        | 63.1                               | 30.6                     | 462                        | 0                        | 30                                             | 0              |
| Northwest Corner                    |        | 62.7                               | 30.8                     | 470                        | 0                        | 28                                             | 0              |
| NE Corner                           |        | 62.5                               | 30.5                     | 479                        | 0                        | 30                                             | 0              |
| Playground South                    |        | 62.9                               | 30.1                     | 500                        | 0                        | 32                                             | 0              |
| North Entrance                      |        | 63.2                               | 30.8                     | 490                        | 0                        | 25                                             | 0              |
| South Entrance                      |        | 62.8                               | 30.2                     | 470                        | 0                        | 31                                             | 0              |
| SE Corner                           |        | 62.6                               | 30.4                     | 481                        | 0                        | 20                                             | 0              |
| SW Corner                           |        | 62.9                               | 30.6                     | 515                        | 0                        | 31                                             | 0              |
| Hall by Elevator                    |        | 69.9                               | 31.3                     | 530                        | 0                        | 13                                             | 0              |
| Dance Room                          |        | 70.1                               | 31.5                     | 521                        | 0                        | 12                                             | 0              |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68 -75°F/winter<br>73 -79°F/summer | 30-60%                   | Outdoor level +<br>700 ppm | 9 ppm                    | 65 ug/m <sup>3</sup><br>24-hour average        | 1 ppm          |

Comments: \_\_\_\_\_

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature:  Date: 1/28/02

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

TIME 15:45

LOCATION PS89 M DATE 1/28/02 PROJECT NO. 19125-297

| Location                            | Occup. | Temperature (°F)                   | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates(ug/m³) | TVOGs (ppm) |
|-------------------------------------|--------|------------------------------------|-----------------------|----------------------------|-----------------------|--------------------------------|-------------|
| South Exit                          | —      | 70.5                               | 30.3                  | 514                        | 0                     | 15                             | 0           |
| North Exit                          | —      | 69.5                               | 30.7                  | 580                        | 0                     | 19                             | 0           |
| 501                                 | —      | 73.5                               | 28.6                  | 520                        | 0                     | 16                             | 0           |
| Hall by Elevator                    | —      | 73.6                               | 28.2                  | 540                        | 0                     | 20                             | 0           |
| 506                                 | —      | 73.2                               | 28.2                  | 557                        | 0                     | 22                             | 0           |
| 510 (Hall)                          | —      | 72.9                               | 28.3                  | 589                        | 0                     | 22                             | 0           |
| Hall by stair 2                     | —      | 72.1                               | 27.6                  | 590                        | 0                     | 23                             | 0           |
| 528                                 | —      | 71.1                               | 27.4                  | 630                        | 0                     | 21                             | 0           |
| 432                                 | —      | 70.5                               | 26.8                  | 546                        | 0                     | 18                             | 0           |
| 428 (Hall)                          | —      | 70.6                               | 26.6                  | 535                        | 0                     | 20                             | 0           |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68 -75°F/winter<br>73 -79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m³<br>24-hour average    | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: Jay Chen Date: 1/28/02

**ATC ASSOCIATES, INC.**  
**INDOOR AIR QUALITY FIELD REPORT**

Page 3 of 3

TIME 16:00

LOCATION P589 M


DATE 1/28/02

PROJECT NO. 19125-297

| Location                            | Occup. | Temperature (°F)                 | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates(ug/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|----------------------------------|-----------------------|----------------------------|-----------------------|---------------------------------------------|-------------|
| 426                                 |        | 70.5                             | 26.8                  | 532                        | 0                     | 20                                          | 0           |
| 408 (Hall)                          |        | 71.0                             | 26.9                  | 570                        | 0                     | 21                                          | 0           |
| 401                                 |        | 71.7                             | 26.9                  | 572                        | 0                     | 16                                          | 0           |
| 302 (Hall)                          |        | 71.9                             | 26.3                  | 530                        | 0                     | 20                                          | 0           |
| Gym (Hall)                          |        | 71.3                             | 26.0                  | 503                        | 0                     | 21                                          | 0           |
| 310                                 |        | 71.2                             | 26.0                  | 513                        | 0                     | 20                                          | 0           |
| 332 (Hall)                          |        | 70.1                             | 25.8                  | 481                        | 0                     | 23                                          | 0           |
| 230 (Hall)                          |        | 69.9                             | 26.0                  | 488                        | 0                     | 22                                          | 0           |
| Auditorium                          |        | 70.5                             | 26.2                  | 520                        | 0                     | 22                                          | 0           |
| 201                                 |        | 71.8                             | 26.0                  | 503                        | 0                     | 17                                          |             |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68-75°F/winter<br>73-79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average     | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 1/28/02

CITY\_21MC100\_003270173