

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 01-28-02

CLIENT: NYC BOE

PROJECT ADDRESS: PS 89 M
201 Warren St, New York, NY 10282

PROJECT NO: 41617-0562

SAMPLED BY: Y.Efstathiou

SAMPLE DATE: 01-25-02
DATE RECEIVED: 01-25-02
DATE ANALYZED: 01-25-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS


SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT
01	9650	1st Floor Hallway - East Side of Cafeteria - Floor	<9.0	9.0
02	9650	1st Floor Hallway - South Side of Cafeteria - Floor	<9.0	9.0
03	9650	Cafeteria - Floor	<9.0	9.0
04	9650	Auditorium - Floor	<9.0	9.0
05	9650	Classroom #226 North Side - Window Sill	<3.2	3.2
06	9650	Classroom #304 (East Side Ventilator) - Floor	<9.0	9.0
07	9650	Classroom #202 (South Side Ventilator) - Window Sill	<1.7	1.7
08	9650	2nd Floor Hallway - South End - Floor	<9.0	9.0
09	9650	4th Floor Hallway - South End - Floor	<9.0	9.0
10	9650	Gymnasium - Floor	<9.0	9.0
11	9650	Blank	<9.0	9.0

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:
 HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.


ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: 

REPORT PREPARED BY: 0582

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: 

LABORATORY DIRECTOR: 

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).