

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 02-15-02

CLIENT: NYC BOE

PROJECT ADDRESS: P. S. 89M/201 Warren St.
New York, NY 10282

PROJECT NO: 41617-0562

SAMPLED BY: M. Medinets

SAMPLE DATE: 02-15-02

DATE RECEIVED: 02-15-02

DATE ANALYZED: 02-15-02

SAMPLE MEDIA: Dust Wipe Sample

ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT
01	9674	1st Floor Hallway East of Cafeteria Floor	<9.0	9.0
02	9674	1st Floor Hallway East of Cafeteria Floor	10.2	9.0
03	9674	1st Floor Hallway East of Cafeteria Floor	<9.0	9.0
04	9666	Auditorium Floor	<9.0	9.0
05	9674	Auditorium Floor	<9.0	9.0
06	9674	Auditorium Floor	<9.0	9.0
07	9674	Classroom #306 South Side Unit Vent Window Sill	<5.1	5.1
08	9674	Classroom #306 South Side Unit Vent Window Sill	<5.5	5.5
09	9674	Classroom #306 South Side Unit Vent Window Sill	<5.0	5.0
10	9674	2nd Floor Hallway South End Floor	<9.0	9.0
11	9666	2nd Floor Hallway South End Floor	<9.0	9.0
12	9674	2nd Floor Hallway South End Floor	<9.0	9.0
13	9674	Blank	<9.0	9.0

NOTE 1:
THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:
 HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.