

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Received: 8/19/02

6:00:00 PM

ATC Group #: 8719

Analysis Date: 8/20/02

Project: PS 89M 201 Warren Street, New York, NY

All Floors, Playground, Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8719 -1	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
02 8719 -2	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
03 8719 -3	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
04 8719 -4	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
05 8719 -5	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
06 8719 -6	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
07 8719 -7	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 2

CITY_21MC100_003270306

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 8/19/02 6:00:00 PM
 ATC Group #: 8719
 Analysis Date: 8/20/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY
 All Floors, Playground, Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
08 8719 -8	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
09 8719 -9	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
10 8719 -10	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
11 8719 -11	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
12 8719 -12	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
13 8719 -13	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
14 8719 -14	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
15 8719 -15	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
16 8719 -16	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879