

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Project: New Stuyvesant H. S.

345 Chambers St., NY, NY

Received: 9/5/02

4:00:00 PM

ATC Group #: 8810

Analysis Date: 9/6/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
01 8810 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
02 8810 -2	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
03 8810 -3	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
04 8810 -4	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
05 8810 -5	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
06 8810 -6	1912.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
07 8810 -7	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 9/5/02 4:00:00 PM
 ATC Group #: 8810
 Analysis Date: 9/6/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: New Stuyvesant H. S.
 345 Chambers St., NY, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
08 8810 -8	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
09 8810 -9	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
10 8810 -10	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
11 8810 -11	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
12 8810 -12	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
13 8810 -13	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
14 8810 -14	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
15 8810 -15	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
16 8810 -16	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 9/5/02 4:00:00 PM
 ATC Group #: 8810
 Analysis Date: 9/6/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S.
 345 Chambers St., NY, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
17 8810 -17	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
18 8810 -18	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
19 8810 -19	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
20 8810 -20	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
21 8810 -21	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879