

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 6

LOCATION PS/30 M DATE 10/16/01 PROJECT NO. 19125-0276
5th floor

Location	Temperature (F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
514	74.9	54.4	505	0.0	18	0.0
511	74.7	52.1	431	0.0	18	0.0
Assistant Principal	73.1	50.0	603	0.0	19	0.0
509	73.2	50.5	594	0.0	21	0.0
506	72.7	50.5	632	0.0	24	0.0
505	72.3	50.2	660	0.0	23	0.0
502	73.4	53.2	543	0.0	26	0.0
501	73.3	53.2	572	0.0	25	0.0
^{Elevator} Holding 5th floor	73.2	50.6	525	0.0	22	0.0
Holding 5th floor middle	72.7	50.8	532	0.0	24	0.0
Guideline levels ASHRAE/AIHA	69-76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

W. open

AC on

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 10/16/01

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 6

LOCATION PS/30M
4th floorDATE 10/16/01 PROJECT NO. 14125-0276

Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOC (ppm)
401	75.8	54.8	720	0.0	29	0.0
404	75.4	53.9	636	0.0	26	0.0
405	74.9	53.6	609	0.0	26	0.0
Hallway by Bathrooms	74.8	53.7	598	0.0	26	0.0
407	74.2	51.1	602	0.0	23	0.0
408	74.1	51.3	567	0.0	23	0.0
409	74.6	52.7	568	0.0	23	0.0
Hallway by Elevator	74.9	51.4	502	0.0	15	0.0
411	74.9	50.7	472	0.0	16	0.0
Gym	72.5	51.1	540	0.0	12	0.0
Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 10/16/01

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 6

LOCATION PS 130M DATE 10/16/01 PROJECT NO. 19125-0276
3rd floor

Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
313	75.1	50.9	439	0.0	17	0.0
311	75.2	51.2	460	0.0	16	0.0
314	75.7	51.0	464	0.0	15	0.0
Hallway Middle	76.0	50.8	465	0.0	17	0.0
308	75.2	49.8	455	0.0	24	0.0
305	74.9	50.9	456	0.0	23	0.0
304	74.8	50.9	472	0.0	23	0.0
303	74.8	51.0	499	0.0	25	0.0
301	75.4	50.7	458	0.0	22	0.0
302	75.6	50.6	552	0.0	21	0.0
Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 10/16/01

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 6

LOCATION PS/30M DATE 10/16/01 PROJECT NO. 19125-0276
2nd floor

Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOC (ppm)
202	76.3	50.7	490	0.0	20	0.0
203	75.8	50.2	485	0.0	20	0.0
Hallway Middle	75.7	49.9	474	0.0	18	0.0
General office	75.6	49.7	467	0.0	19	0.0
Principal	75.8	49.8	529	0.0	20	0.0
208	75.3	49.8	507	0.0	21	0.0
210	75.1	49.7	498	0.0	21	0.0
212	75.4	50.1	505	0.0	20	0.0
213	75.8	50.0	484	0.0	17	0.0
216	76.3	49.9	480	0.0	17	0.0
Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

under
open

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 10/16/01

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 6

LOCATION PS130M DATE 10/16/01 PROJECT NO. 19125-0276
2nd floor

Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
217	76.5	50.1	502	0.0	17	0.0
Hallway by 217	76.5	50.0	511	0.0	24	0.0
Stair case D	76.7	51.9	580	0.0	18	0.0
Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____ Date: 10/16/01

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 6LOCATION PS 130MDATE 10/16/01PROJECT NO. 14125-02761st floor

Location	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOC (ppm)
Cafeteria	76.9	53.2	769	0.0	19	0.0
Auditorium	75.9	49.9	490	0.0	19	0.0
Cafeteria by stair A	75.6	49.4	440	0.0	18	0.0
Community Room	75.8	49.0	469	0.0	20	0.0
Hallway by stair B	75.0	49.1	406	0.0	19	0.0
Main Entrance Lobby	74.9	50.4	466	0.0	18	0.0
Outdoor	69.7	51.1	360	0.0	35	0.0
Guideline levels ASHRAE/AIHA	69 - 76°F/winter 73-78.5°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	50 ug/m ³	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 10/16/01