NYC 9/11 Public Portal Document

EMSL Analytical, Inc.
307 West 38th Street, New York, NY 10018
Phone: 212-290-0051 Fax: 2122900058 Email: manhattanlab@emsl.com

6-29-02

Attn: JLC Environmental Consultants, Inc.
200 Park Ave South
Suite 1106
New York, NY 10003
Fax: (212) 420-6092 Phone: 212-420-8119
Project: 01-2159-01 / NYC DEP / 100 TRINITY PLACE, N.Y.

Customer ID: JLCC50
Customer PO:
Received: 06/29/02 4:47 PM

EMSL Order: 030208791
EMSL Project ID:

Analysis Date: 6/30/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ -5µ	# Structure ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
01 030208791-0001	1200.00	0.0750	0	None Detected			0.0043	<13.33	<0.0043	

Analyst(s)
Roy Cross (1)

Laboratory Manager
or other approved signatory

Disclaimers: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.
Accredited for NVLAP PLM/TEM #101048-9, NY State ELAP #11506

TEMAHERA-1

CITY_DEP_WORBY_CANNATA_SUBP_000034549

NYC-WTC_000202770