

EMSL Analytical, Inc.

307 West 38th Street, New York, NY 10018

Phone: 212-298-0051 Fax: 212-298-0058 Email: nranhattanlab@emsl.com

EMSL

Attn: JLO Environmental Consultants, Inc.
200 Park Ave South
Suite 1106
New York, NY 10003

Fax: (212) 420-6092

Phone: 212-420-8119

Project: 01-2159-03 / DEP / P.S. 234

Customer ID: JLCC50

Customer PO:

Received: 06/29/02 4 46 PM

EMSL Order: 030208793

EMSL Project ID:

Analysis Date: 6/30/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²) (S/cc)	Notes
01 030208793-0001	1200.00	0.0750	0	None Detected		0.0043	<13.33 <0.0043	

Analyst(s)

Rey Cross (1)

Laboratory Manager
or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101048-S, NY State ELAP #11506

TEMAHERA-1

1