

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSL

Attn: CTSI-Consulting & Testing Services, Inc.
622 Georges Rd.
North Brunswick, NJ 08902

Fax: (732) 729-1803 Phone: 732-729-1800

Project: 115 Broadway / 22nd Floor

Customer ID: CTSI50
Customer PO:
Received: 10/01/01 8:15 PM
EMSL Order: 030105239
EMSL Project ID:
Analysis Date: 10/1/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
01 030105239-0001	Trinity Level Center	10/1/2001	1440.00	12.0	100	0.002	15.29	0.004	
02 030105239-0002	22nd Floor West side	10/1/2001	1520.00	29.0	100	0.002	36.94	0.009	
03 030105239-0003	22nd Floor East side	10/1/2001	1520.00	39.5	100	0.002	50.32	0.013	
04 030105239-0004	22nd Floor West side	10/1/2001	1000.00	43.0	100	0.003	54.78	0.021	
05 030105239-0005	22nd Floor East side	10/1/2001	1000.00	31.0	100	0.003	39.49	0.015	
06 030105239-0006	Trinity Level / West side	10/1/2001	1800.00	6.0	100	0.001	7.64	0.002	
07 030105239-0007	Trinity Level / Center	10/1/2001	1800.00	10.0	100	0.001	12.74	0.003	
08 030105239-0008	Trinity Level / East side	10/1/2001	1800.00	16.0	100	0.001	20.38	0.004	
09 030105239-0009	22nd Floor West side	10/1/2001	1800.00	11.0	100	0.001	14.01	0.003	
10 030105239-0010	22nd Floor Center	10/1/2001	1800.00	14.0	100	0.001	17.83	0.004	
11 030105239-0011	22nd Floor East side	10/1/2001	1800.00	8.0	100	0.001	10.19	0.002	
12 030105239-0012	Blank	10/1/2001	0.00	<5.5	100		<7.0		Field Blank

Ram Yallabandi

Analyst



Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.

Analysis performed by EMSL Manhattan (NY State ELAP #11506)

PCM-1

1

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

EMSL

Attn: CTSI-Consulting & Testing Services, Inc.
622 Georges Rd.
North Brunswick, NJ 08902

Fax: (732) 729-1803 Phone: 732-729-1800

Project: 115 Broadway / 22nd Floor

Customer ID: CTSI50
Customer PO:
Received: 10/01/01 8:15 PM
EMSL Order: 030105239
EMSL Project ID:
Analysis Date: 10/1/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
13	Blank	10/1/2001	0.00	<5.5	100		<7.0		Field Blank
030105239-0013									

Ram Yallabandi

Analyst



Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.

Analysis performed by EMSL Manhattan (NY State ELAP #11506)

PCM-1

2