

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSL

Attn: CTSI-Consulting & Testing Services, Inc.
622 Georges Rd.
North Brunswick, NJ 08902
Fax: (732) 729-1803 Phone: 732-729-1800
Project: 115 BROADWAY/ENTIRE BLDG

Customer ID: CTSI50
Customer PO:
Received: 10/07/01 3:00 PM
EMSL Order: 030105621
EMSL Project ID:
Analysis Date: 10/8/01

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
01	22nd FI Center	10/7/01	1800.00	6.0	100	0.001	7.64	0.002	
030105621-0001									
02	21st FI Center	10/7/01	1800.00	13.0	100	0.001	16.56	0.004	
030105621-0002									
03	20th FI Center	10/7/01	1800.00	8.0	100	0.001	10.19	0.002	
030105621-0003									
04	19th FI Center	10/7/01	1800.00	19.5	100	0.001	24.84	0.005	
030105621-0004									
05	18th FI Center	10/7/01	1800.00	14.0	100	0.001	17.83	0.004	
030105621-0005									
06	17th FI Center	10/7/01	1800.00	15.0	100	0.001	19.11	0.004	
030105621-0006									
07	16th FI Center	10/7/01	1800.00	26.0	100	0.001	33.12	0.007	
030105621-0007									
08	15th FI Center	10/7/01	1800.00	14.0	100	0.001	17.83	0.004	
030105621-0008									
09	14th FI Center	10/7/01	1800.00	14.0	100	0.001	17.83	0.004	
030105621-0009									
10	13th FI Center	10/7/01	1800.00	9.0	100	0.001	11.46	0.003	
030105621-0010									
11	12th FI Center	10/7/01	1800.00	8.0	100	0.001	10.19	0.002	
030105621-0011									
12	2nd FI Center	10/7/01	1800.00	<5.5	100	0.001	<7.0	<0.001	
030105621-0012									

Dan Osborne

Analyst



 Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506)

PCM-1

1

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSL

Attn: CTSI-Consulting & Testing Services, Inc.
622 Georges Rd.
North Brunswick, NJ 08902

Fax: (732) 729-1803 Phone: 732-729-1800

Project: 115 BROADWAY/ENTIRE BLDG


Customer ID: CTSI50
Customer PO:
Received: 10/07/01 3:00 PM
EMSL Order: 030105621
EMSL Project ID:
Analysis Date: 10/8/01

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
13	3rd FI Center	10/7/01	1800.00	6.0	100	0.001	7.64	0.002	
030105621-0013									
14	4th FI Center	10/7/01	1800.00	6.0	100	0.001	7.64	0.002	
030105621-0014									
15	5th FI Center	10/7/01	1815.00	<5.5	100	0.001	<7.0	<0.001	
030105621-0015									
16	Lobby Center	10/7/01	1815.00	9.0	100	0.001	11.46	0.002	
030105621-0016									
17	Trinity Level Center	10/7/01	1800.00	8.0	100	0.001	10.19	0.002	
030105621-0017									
18	Outside Bldg by Entrance	10/7/01	1785.00	7.0	100	0.002	8.92	<0.002	
030105621-0018									
19	11th FI Center	10/7/01	1800.00	<5.5	100	0.001	<7.0	<0.001	
030105621-0019									
20	10th FI Center	10/7/01	1800.00	14.0	100	0.001	17.83	0.004	
030105621-0020									
21	9th FI Center	10/7/01	1800.00	7.0	100	0.001	8.92	0.002	
030105621-0021									
22	8th FI Center	10/7/01	1800.00	19.5	100	0.001	24.84	0.005	
030105621-0022									
23	7th FI Center	10/7/01	1800.00	12.0	100	0.001	15.29	0.003	
030105621-0023									
24	6th FI Center	10/7/01	1800.00	24.0	100	0.001	30.57	0.006	
030105621-0024									

Dan Osborne

Analyst


 Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.

Analysis performed by EMSL Manhattan (NY State ELAP #11506)

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSL

Attn: CTSI-Consulting & Testing Services, Inc.
622 Georges Rd.
North Brunswick, NJ 08902
Fax: (732) 729-1803 Phone: 732-729-1800
Project: 115 BROADWAY/ENTIRE BLDG

Customer ID: CTSI50
Customer PO:
Received: 10/07/01 3:00 PM
EMSL Order: 030105621
EMSL Project ID:
Analysis Date: 10/8/01

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
25 030105621-0025	Field Blank	10/7/01	0.00	<5.5	100		<7.0		Field Blank
26 030105621-0026	Field Blank	10/7/01	0.00	<5.5	100		<7.0		Field Blank
27 030105621-0027	Field Blank	10/7/01	0.00	<5.5	100		<7.0		Field Blank

Dan Osborne

Analyst



Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
Analysis performed by EMSL Manhattan (NY State ELAP #11506)

PCM1

3