

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSLAttn: CTSI-Consulting & Testing Services, Inc.
622 Georges Rd.
North Brunswick, NJ 08902

Fax: (732) 729-1803 Phone: 732-729-1800

Project: 115 BROADWAY/BASEMENT/AQ

Customer ID: CTSI50

Customer PO:

Received: 10/11/01 5:30 PM

EMSL Order: 030106038

EMSL Project ID:

Analysis Date: 10/12/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ³	Fibers/ cc	Notes
1 030106038-0001	BASEMENT N-W SIDE EL. ROOM	10/11/2001	1800.00	<5.5	100	0.001	<7.0	<0.001	
2 030106038-0002	BASEMENT N-W SIDE EL. ROOM	10/11/2001	1800.00	<5.5	100	0.001	<7.0	<0.001	
3 030106038-0003	BLANK	10/11/2001	0.00	<5.5	100		<7.0		Field Blank
4 030106038-0004	BLANK	10/11/2001	0.00	<5.5	100		<7.0		Field Blank



Dawnette Branson

Analyst

Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm³. The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.

Analysis performed by EMSL Manhattan (NY State ELAP #11506)

PCM-1

1