

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

EMSLAttn: CTSI-Consulting & Testing Services, Inc.
622 Georges Rd.
North Brunswick, NJ 08902

Fax: (732) 729-1803

Phone: 732-729-1800

Project: 115 Broadway / All Floors

Customer ID: CTSI50

Customer PO:

Received: 10/12/01 6:30 PM

EMSL Order: 030106084

EMSL Project ID:

Analysis Date: 10/13/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ³	Fibers/ cc	Notes
01	Outside of Bldg	10/12/2001	1845.00	16.0	100	0.001	20.38	0.004	
030106084-0001									
02	Lobby in the middle	10/12/2001	1830.00	19.0	100	0.001	24.2	0.005	
030106084-0002									
03	Trinity level	10/12/2001	1815.00	6.0	100	0.001	7.64	0.002	
030106084-0003									
04	3rd floor in the middle	10/12/2001	1875.00	21.0	100	0.001	26.75	0.005	
030106084-0004									
05	5th floor in the middle	10/12/2001	1860.00	5.5	100	0.001	7.01	0.002	
030106084-0005									
06	6th floor in the middle	10/12/2001	1860.00	6.0	100	0.001	7.64	0.002	
030106084-0006									
07	7th floor in the middle	10/12/2001	1860.00	<5.5	100	0.001	<7.0	<0.001	
030106084-0007									
08	8th floor in the middle	10/12/2001	1815.00	6.5	100	0.001	8.28	0.002	
030106084-0008									
09	9th floor in the middle	10/12/2001	1830.00	7.0	100	0.001	8.92	0.002	
030106084-0009									
10	10th floor in the middle	10/12/2001	1830.00	<5.5	100	0.001	<7.0	<0.001	
030106084-0010									
11	2nd floor in the middle	10/12/2001	1800.00	<5.5	100	0.001	<7.0	<0.001	
030106084-0011									
12	4th floor in the middle	10/12/2001	1755.00	8.0	100	0.002	10.19	0.002	
030106084-0012									

Thomas Michel

Analyst

Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm³. The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.

Analysis performed by EMSL Manhattan (NY State ELAP #11506)

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0058 Email:

EMSLAttn: CTSI-Consulting & Testing Services, Inc.
622 Georges Rd.
North Brunswick, NJ 08902

Fax: (732) 729-1803

Phone: 732-729-1800

Project: 115 Broadway / All Floors

Customer ID: CTSI50

Customer PO:

Received: 10/12/01 6:30 PM

EMSL Order: 030106084

EMSL Project ID:


Analysis Date: 10/13/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ²	Fibers/ cc	Notes
13 030106084-0013	11th floor in the middle	10/12/2001	1665.00	6.0	100	0.002	7.64	<0.002	
14 030106084-0014	12th floor in the middle	10/12/2001	1800.00	15.0	100	0.001	19.11	0.004	
15 030106084-0015	13th floor in the middle	10/12/2001	1800.00	<5.5	100	0.001	<7.0	<0.001	
16 030106084-0016	14th floor in the middle	10/12/2001	1820.00	<5.5	100	0.001	<7.0	<0.001	
17 030106084-0017	15th floor in the middle	10/12/2001	1800.00	<5.5	100	0.001	<7.0	<0.001	
18 030106084-0018	16th floor in the middle	10/12/2001	1785.00	6.0	100	0.002	7.64	<0.002	
19 030106084-0019	17th floor in the middle	10/12/2001	1800.00	10.0	100	0.001	12.74	0.003	
20 030106084-0020	18th floor in the middle	10/12/2001	1815.00	20.0	100	0.001	25.48	0.005	
21 030106084-0021	19th floor in the middle	10/12/2001	1800.00	<5.5	100	0.001	<7.0	<0.001	
22 030106084-0022	20th floor in the middle	10/12/2001	1815.00	<5.5	100	0.001	<7.0	<0.001	
23 030106084-0023	21th floor in the middle	10/12/2001	1815.00	8.5	100	0.001	10.83	0.002	
24 030106084-0024	22th floor in the middle	10/12/2001	1815.00	20.0	100	0.001	25.48	0.005	

Thomas Michel

Analyst

Laboratory Manager
or other approved signatory

Limit of detection is 7 fibers/mm². The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.

Analysis performed by EMSL Manhattan (NY State ELAP #11506)

PCM 1

2

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 2122900058 Email:

EMSL

Attn: CTSI-Consulting & Testing Services, Inc.
 622 Georges Rd.
 North Brunswick, NJ 08902
 Fax: (732) 729-1803 Phone: 732-729-1800
 Project: 115 Broadway / All Floors

Customer ID: CTSI50
 Customer PO:
 Received: 10/12/01 6:30 PM
 EMSL Order: 030106084
 EMSL Project ID:
 Analysis Date: 10/13/2001

Fiber Analysis of Air Samples via NIOSH 7400, Revision 3, Issue 2, 8/15/94

Sample	Location	Sample Date	Volume	Fibers	Fields	LOD (fib/cc)	Fibers/ mm ³	Fibers/ cc	Notes
25	Blank	10/12/2001	0.00	<5.5	100		<7.0		Field Blank
030106084-0025									
26	Blank	10/12/2001	0.00	<5.5	100		<7.0		Field Blank
030106084-0026									
27	Blank	10/12/2001	0.00	<5.5	100		<7.0		Field Blank
030106084-0027									

Thomas Michel

Analyst



Laboratory Manager
 or other approved signatory

Limit of detection is 7 fibers/mm³. The laboratory is not responsible for data reported in fibers/cc, which is dependent on volume collected by non-laboratory personnel. This report relates only to the samples reported above. This report may not be reproduced, except in full, without written approval by EMSL.
 Analysis performed by EMSL Manhattan (NY State ELAP #11506)