

Aug 23 04 10:18a

RJ Lee Group, Inc.350 Hochberg Road, Monroeville, PA
Phone: (724) 325-1776 Fax: (724) 731**Final Laboratory Report**
TEM Air AnalysisRJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USAReport Date: 8/20/2004
Sample Receipt Date: 8/19/2004
RJ Lee Group Job No.: A FH306366-1019
Samples Received: 10
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start Stop	Floor	Grid	Sub Location	Filter Area (mm ²)	Volume (liter)	Area Analyzed (mm ²)	Asbestos Structures Chry Amph	Concentration Analytical Sensitivity	
										(S/mm ²)	(S/c)
5228383.HT	Field Blank	8/17/2004 8/17/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08982	0 0	< 11.1 11.1	N/A N/A
5228384.HT	Area	8/17/2004 8/17/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	1948.00	0.04491	0 0	< 22.3 22.3	< 0.004 0.004
5228385.HT	Area	8/17/2004 8/17/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	1940.00	0.04491	0 0	< 22.3 22.3	< 0.004 0.004
5228386.HT	Area	8/17/2004 8/17/2004	99	N/A	(East) - Greenwich	385	1940.00	0.04491	0 0	< 22.3 22.3	< 0.004 0.004
5228387.HT	Area	8/17/2004 8/17/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	1932.00	0.04491	0 0	< 22.3 22.3	< 0.004 0.004
5229740.HT	Field Blank	8/17/2004 8/17/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08982	0 0	< 11.1 11.1	N/A N/A
5229741.HT	Area	8/17/2004 8/18/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2020.00	0.04491	0 0	< 22.3 22.3	< 0.004 0.004
5229742.HT	Area	8/17/2004 8/18/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2146.25	0.03593	0 0	< 27.8 27.8	< 0.005 0.005
5229743.HT	Area	8/17/2004 8/18/2004	99	N/A	(East) - Greenwich	385	2016.00	0.04491	0 0	< 22.3 22.3	< 0.004 0.004
5229744.HT	Area	8/17/2004 8/18/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2024.00	0.04491	0 0	< 22.3 22.3	< 0.004 0.004

Notes:

- Volumes provided by Ambient were used to calculate analytical results and sensitivities.
- "<" indicates results less than analytical sensitivity. "—" indicates that sample was not analyzed.
- Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
- If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
- Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
- Samples will be held for 90 days and then disposed of per Federal regulations.
- These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data

Page 1 of 3