NYC 9/11 Public Portal Document

6/5

RJ LeeGroup, Inc.

350 Hochberg Road, Monroeville, PA 15146
Phone: (724) 325-1776 Fax: (724) 733-1799

Final Laboratory Report

TEM Air Analysis

RJ Lee Group, Inc.
350 Hochberg Road
Monroeville, PA 15146
USA

Report Date: 6/8/2004
Sample Receipt Date: 6/7/2004
RJ Lee Group Job No.: ATH306366-769
Samples Received: 11
Building: 130 Liberty

Method: Federal Register, 40 CFR, Part 763, October 30, 1987

RJLG Sample Number	Sample Type	Date Collected Start / Stop	Floor	Grid	Sub Location	Filter Area (mm^2)	Volume (liter)	Area Analyzed (mm^2)	Asbestos Structures Chry	Asbestos Structures Amph	Concentration Analytical Sensitivity (S/mm^2)	Concentration Analytical Sensitivity (S/cc)
5220066.HT	Area	6/5/2004 6/5/2004	0	Z	(South) - Decon Exit	385	1968.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220068.HT	Area	6/5/2004 6/5/2004	0	Y	(South) - Decon Entrance	385	2012.00	0.04268	0	0	< 23.4 23.4	< 0.004 0.004
5220067.HT	Area	6/5/2004 6/5/2004	0	FF	(South) - Shanty Area	385	1972.00	0.04268	0	0	< 23.4 23.4	< 0.005 0.005
5220070.HT	Field Blank	6/5/2004 6/5/2004	0	X	(South) - Ramp	385	0.000	0.08537	0	0	< 11.7 11.7	N/A N/A
5220069.HT	Area	6/5/2004 6/5/2004	0	X	(South) - Ramp	385	2024.00	0.04268	1	0	23.4 23.4	0.004 0.004
5220071.HT	Field Blank	6/5/2004 6/5/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	0.000	0.08537	0	0	< 11.7 11.7	N/A N/A
5220072.HT	Area	6/5/2004 6/5/2004	99	Not Acquired	(SouthWest) - Washington and Albany	385	2024.00	0.04268	0	0	< 23.4 23.4	< 0.004 0.004
5220073.HT	Area	6/5/2004 6/5/2004	99	Not Acquired	(SouthEast) - Greenwich and Albany	385	2036.00	0.04268	0	0	< 23.4 23.4	< 0.004 0.004
5220074.HT	Area	6/5/2004 6/5/2004	99	N/A	(East) - Greenwich	385	2044.00	0.04268	0	0	< 23.4 23.4	< 0.004 0.004
5220075.HT	Area	6/5/2004 6/5/2004	99	Not Acquired	(NorthWest) - Washington and Cedar	385	2056.00	0.04268	0	0	< 23.4 23.4	< 0.004 0.004

Notes:
1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "---" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

CITY_DEP_WORBY_CANNATA_SUBP_000035382

NYC-WTC_000202832

NYC 9/11 Public Portal Document

RJ Lee Group, Inc.

Laboratory Report (cont.)

RJ Lee Group Job No: ATH306366-769
Building: 130 Liberty

RJ Lee Group, Inc.
Report Date: 6/8/2004

RJLG Sample Number	Sample Type	Date Collected Start / Stop	Floor	Grid	Sub Location	Filter Area (mm^2)	Volume (liter)	Area Analyzed (mm^2)	Asbestos Structures Chry	Asbestos Structures Amph	Concentration Analytical Sensitivity (S/mm^2)	Concentration Analytical Sensitivity (S/cc)
5220076.HT	Area	6/5/2004 6/5/2004	1	K	(NorthWest) - Cedar Decon	385	2072.00	0.04268	0	0	< 23.4 23.4	< 0.004 0.004

Authorized Signature: /s/b
Kimberly A. Ailison, Manager - TEM Analysis

Notes:
1. Volumes provided by Ambient were used to calculate analytical results and sensitivities.
2. "<" indicates results less than analytical sensitivity. "---" indicates that sample was not analyzed.
3. Sample(s) for this project were analyzed at our: Monroeville, PA (NVLAP #101208-0, NY ELAP #10844) facility.
4. If RJ Lee Group, Inc. did not collect the samples analyzed, the verifiability of the laboratory's results are limited to the reported values.
5. Abbreviations: N/A-Not Applicable, Chry-Chrysotile Asbestos, Amph-Amphibole Asbestos, S-Structures.
6. Samples will be held for 90 days and then disposed of per Federal regulations.
7. These results are submitted pursuant to RJ Lee Group's current terms and conditions of sale, including the company's standard warranty and limitation of liability provisions. No responsibility or liability is assumed for the manner in which these results are used or interpreted.

See Appendix A for fiber data.

CITY_DEP_WORBY_CANNATA_SUBP_000035383

NYC-WTC_000202833