

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 10-21-02
CLIENT: ATC Associates Inc. - New York
PROJECT NAME: DEP
125 Cedar Street, NY, NY
JOB #: 15-22906-0002
SAMPLED BY: R. Fishman
SAMPLE DATE: 10-21-02
DATE RECEIVED: 10-21-02
DATE ANALYZED: 10-21-02
SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
01	10059	11th Floor North Livingroom	14.7	9.0
02	10059	Field Blank	<9.0 μg	9.0 μg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$,
Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

NOTE 3:

Blank units are in μg

CERTIFICATION AND SIGNATURES

ANALYSIS PERFORMED BY: TL

REPORT PREPARED BY: mm

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: mm

LABORATORY DIRECTOR: mm

ATC is accredited by the New York State Department of Health Environmental Laboratory Approval Program (ELAP) and by the American Industrial Hygiene Association (AIHA) to perform analysis of lead in paint, dust wipes, air and soil samples. (ELAP #10879), (AIHA #100229).

ATC ASSOCIATES INC.
104 EAST 25TH STREET
NEW YORK, NY 10010
PHONE: 212-353-8200 FAX: 212-979-8447

10059

CHAIN OF CUSTODY

[illegible]

TOTAL P.01