

SciLab ID #: 203033339

Client Name: JLC Environmental Consultants

Table I
Summary of Transmission Electron Microscopy (TEM) Results for Asbestos (air)
 03-2744; NYC DEP WTC; 114 Liberty Street; NY, NY/DURINGS

SciLab Sample #	Client Sample #	Dilution Factor	Air Filtered (liters)	Area Analyzed (sq. mm.)	* Analytical Sensitivity (struc/cc air)	Asbestos Structures Detected (Microns)			Structure Density (struc/sq. mm.)		Structure Concentration (struc/cc air)		Type of Asbestos
						0.5-5.0	>5.0	Total	>5.0	Total	>5.0	Total	
01	008563		3600	.12	0.0009	0.0	0.0	0.0	<8.3	<8.3	<0.0009	<0.0009	NSD
	During/Inside-Entrance to Bldg., Liberty Street - Northern Side												
02	008564		3600	.12	0.0009	0.0	0.0	0.0	<8.3	<8.3	<0.0009	<0.0009	NSD
	During/Personal Decon Clean Room												
03	008565		3600	.12	0.0009	0.0	0.0	0.0	<8.3	<8.3	<0.0009	<0.0009	NSD
	During/Inside-Eastern Side of Bldg.												
04	008566		3600	.12	0.0009	0.0	0.0	0.0	<8.3	<8.3	<0.0009	<0.0009	NSD
	During/Inside-Entrance to Basement												
05	008567		3600	.12	0.0009	0.0	0.0	0.0	<8.3	<8.3	<0.0009	<0.0009	NSD
	During/Inside of Bldg., Cedar Street Entrance												


* concentration represented by the detection of 1 structure

** not analyzed

NSD: No Asbestos Structures Detected

Reviewed By: _____

; Analyzed By: _____


 Roman Reysakhov

Date: 3/24/03

NVLAP#: 200546-0

CITY_DEP_WORRY_CANNATA_SUBP_000036202