

ATC ASSOCIATES, INC.

Page 1 of 14

TIME 07:15

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 2/20/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
14 th Fl - Hall	0	—	—	—	—	14	—
14 th FL - STUD. CAFE.	0	—	—	—	—	11	—
14 th Fl - Rm #1406	0	—	—	—	—	10	—
14 th Fl - Rm 1403	0	—	—	—	—	9	—
14 th Fl - STAIR B	0	—	—	—	—	10	—
14 th Fl - Rm 1405	0	—	—	—	—	11	—
13 th Fl - STAIR A	0	—	—	—	—	12	—
13 th Fl - Hall	0	—	—	—	—	11	—
13 th Fl - Rm 1306	0	—	—	—	—	11	—
13 th Fl - LIBRARY	0	—	—	—	—	11	—
13 th Fl - Rm 1305	0	—	—	—	—	10	—
13 th Fl - Rm 1311	0	—	—	—	—	10	—
Guideline levels ASHRAE/AHIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does () Does not meet established indoor air quality guidelines.Signature: [Signature]Date: 2/20/02

ATC ASSOCIATES, INC.

Page 2 of 14

TIME 07:43

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE

DATE 2/20/02

PROJECT NO. 19125-0243

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOC's (ppm)
12 th Fl - hall	0	—	—	—	—	11	—
12 th Fl - Rm 1205	0	—	—	—	—	10	—
12 th Fl - Rm 1215	0	—	—	—	—	12	—
12 th Fl - STAIR B	0	—	—	—	—	10	—
11 th Fl - Room 1115	0	—	—	—	—	11	—
11 th Fl - hall	0	—	—	—	—	11	—
11 th Fl - Rm 1109	0	—	—	—	—	12	—
11 th Fl - Rm 1105	0	—	—	—	—	12	—
11 th Fl - Rm 1106	0	—	—	—	—	11	—
10 th Fl - Rm 1005	0	—	—	—	—	10	—
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments:

The assessed location(s) ☒ Does () Does not meet established indoor air quality guidelines.Signature: Date: 2/20/02

ATC ASSOCIATES, INC.

Page 3 of 14

TIME 08:10

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 2/20/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
10 th Fl. Rm 1006	0	—	—	—	—	13	—
10 th Fl. Rm 1009	0	—	—	—	—	12	—
10 th Fl. Rm 1015	0	—	—	—	—	10	—
10 th Fl. STAIR A	0	—	—	—	—	13	—
9 th Fl. Rm #906	0	—	—	—	—	10	—
9 th Fl Rm #905	0	—	—	—	—	11	—
9 th Fl Rm #909	0	—	—	—	—	11	—
9 th Fl Rm #915	0	—	—	—	—	11	—
9 th Fl - Hall	0	—	—	—	—	10	—
8 th Fl. STAIR B	0	—	—	—	—	9	—
Guideline levels ASHRAE/AHIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments:

The assessed location(s) (X) Does () Does not meet established indoor air quality guidelines.

Signature:

[Signature]

Date:

2/20/02

CITY_21MC100_003058984

ATC ASSOCIATES, INC.

Page 4 of 14

TIME 08:35

INDOOR AIR QUALITY FIELD REPORT

(11894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 2/20/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
8 th Fl - Rm 815	0	—	—	—	—	11	—
8 th Fl - Rm 809	0	—	—	—	—	10	—
8 th Fl - Rm 805	0	—	—	—	—	12	—
8 th Hall	0	—	—	—	—	11	—
7 th Fl - Rm 702	0	—	—	—	—	12	—
7 th Fl - Rm 705	0	—	—	—	—	16	—
7 th Fl - Rm 711	0	—	—	—	—	10	—
7 th Fl - Rm 715	0	—	—	—	—	11	—
6 th Fl - STAIR A	0	—	—	—	—	22	—
6 th Fl - Rm 603	0	—	—	—	—	20	—
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 2/20/02

ATC ASSOCIATES, INC.

Page 5 of 14

TIME 08:55

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE

DATE 2/20/02

PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOC's (ppm)
6 th Fl - Rm 609	0	—	—	—	—	19	—
6 th Fl - Rm 615	0	—	—	—	—	10	—
6 th Fl - Rm 610	0	—	—	—	—	12	—
5 th Fl - Rm 503	0	—	—	—	—	11	—
5 th Fl - Rm 506	0	—	—	—	—	14	—
5 th Fl - Rm 509	0	—	—	—	—	17	—
5 th Fl - Rm 515	0	—	—	—	—	18	—
5 th Fl - STAIR B	0	—	—	—	—	14	—
4 th Fl - Hall	0	—	—	—	—	17	—
4 th Fl - Rm 404	0	—	—	—	—	20	—
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 2/20/02

ATC ASSOCIATES, INC.

Page 6 of 14

TIME 09:20

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 2/20/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m ³)	TVOCs (ppm)
4 th Fl. - Rm 415	0	—	—	—	—	22	—
4 th Fl. - Rm 409	0	—	—	—	—	17	—
4 th Fl. - Rm 403	0	—	—	—	—	14	—
3 rd Fl. - Hall	0	—	—	—	—	11	—
3 rd Fl. - Rm 306	0	—	—	—	—	9	—
3 rd Fl. - Rm 309	0	—	—	—	—	10	—
3 rd Fl. - Rm 315	0	—	—	—	—	14	—
2 nd Fl. - Hall	0	—	—	—	—	13	—
2 nd Fl. - Rm 206	0	—	—	—	—	11	—
2 nd Fl. - Rm 202	0	—	—	—	—	16	—
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) (☒ Does () Does not) meet established indoor air quality guidelines.

Signature: _____

Date: 2/20/02

ATC ASSOCIATES, INC.

Page 7 of 14

TIME 09:55

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 2/20/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
1 st Fl - Vestibule	0	—	—	—	—	27	—
1 st Fl - STAIRS A	0	—	—	—	—	22	—
1 st Fl - Rm 123	0	—	—	—	—	17	—
BSMT - Hall	0	—	—	—	—	21	—
BSMT Rm #B06	0	—	—	—	—	19	—
BSMT Rm B23	0	—	—	—	—	14	—
BSMT Rm B19	0	—	—	—	—	12	—
Outside of Bldg Adj. to MAIN ENTRANCE OF BLDG	0	—	—	—	—	59	—
Outside - NORTH	0	—	—	—	—	55	—
outside of Bldg South	0	—	—	—	—	90	—
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30 - 60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments:

The assessed location(s) () Does (✓) Does not meet established indoor air quality guidelines.

Signature:

[Signature]

Date:

2/20/02

CITY_21MC100_003058988

ATC ASSOCIATES, INC.

Page 8 of 14

TIME 15:50

INDOOR AIR QUALITY FIELD REPORT

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE (11894)DATE 2/20/02PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
14 th - cafet # 1406	0	—	—	—	—	11	—
14 th - rm # 1403	0	—	—	—	—	6	—
14 th - hallway	0	—	—	—	—	9	—
14 th STAIR A	0	—	—	—	—	7	—
13 th - rm 1306	0	—	—	—	—	8	—
13 th - rm 1311	0	—	—	—	—	7	—
13 th - rm 1305	0	—	—	—	—	10	—
13 th - hallway	0	—	—	—	—	9	—
13 th STAIR B	0	—	—	—	—	7	—
12 th - rm 1215	0	—	—	—	—	8	—
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does () Does not meet established indoor air quality guidelines.Signature: [Signature] Date: 2/20/02

ATC ASSOCIATES, INC.

Page 9 of 14

TIME 16:10

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE

DATE 2/20/02

PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
12 th - Rm 1205	0	—	—	—	—	11	—
12 th - hallway	0	—	—	—	—	10	—
12 th - Rm 1206	0	—	—	—	—	9	—
12 th - Stairs A	0	—	—	—	—	9	—
11 th - Rm 1105	0	—	—	—	—	10	—
11 th - Rm 1106	0	—	—	—	—	9	—
11 th - Rm 1109	0	—	—	—	—	11	—
11 th - hallway	0	—	—	—	—	10	—
11 th - stairs B	0	—	—	—	—	9	—
10 th - Rm 1015	0	—	—	—	—	7	—
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: _____

2/20/02

ATC ASSOCIATES, INC.

Page 10 of 14

TIME 16:35

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 2/20/02 PROJECT NO. 19125-0290

Location Floor #	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
10 th - rm 1009	0	—	—	—	—	7	—
10 th - rm 1006	0	—	—	—	—	7	—
10 th - hallway	0	—	—	—	—	8	—
10 th - rm 1005	0	—	—	—	—	7	—
9 th - STAIRS B	0	—	—	—	—	9	—
9 th - rm 915	0	—	—	—	—	7	—
9 th - rm - 909	0	—	—	—	—	8	—
9 th - rm 906	0	—	—	—	—	7	—
9 th - Hallway	0	—	—	—	—	7	—
8 th - STAIRS A	0	—	—	—	—	8	—
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments:

The assessed location(s) (X) Does () Does not meet established indoor air quality guidelines.

Signature:



Date:

2/20/02

CITY_21MC100_003058991

ATC ASSOCIATES, INC.

Page 11 of 14

TIME 16:55

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 2/20/02 PROJECT NO. 19125-0290

Floor	Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOC's (ppm)
8 th	Rm 805	0	—	—	—	—	11	—
8 th	hallway	0	—	—	—	—	8	—
8 th	Rm 809	0	—	—	—	—	10	—
8 th	Rm 815	0	—	—	—	—	9	—
7 th	Rm 715	0	—	—	—	—	11	—
7 th	Rm 709	0	—	—	—	—	14	—
7 th	Rm 706	0	—	—	—	—	12	—
7 th	hallway	0	—	—	—	—	10	—
7 th	stairs A	0	—	—	—	—	8	—
6 th	Rm 605	0	—	—	—	—	9	—
Guideline levels ASHRAE/AIHA/EPA			68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 2/20/02

ATC ASSOCIATES, INC.

Page 12 of 14

TIME 17:15

INDOOR AIR QUALITY FIELD REPORT


(11894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 2/20/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
6 th - Rm 609	0	—	—	—	—	11	—
6 th - Rm 815	0	—	—	—	—	12	—
6 th - Stair B	0	—	—	—	—	8	—
5 th - hallway	0	—	—	—	—	10	—
5 th - Rm # 503	0	—	—	—	—	11	—
5 th - Rm # 506	0	—	—	—	—	9	—
5 th - Rm # 509	0	—	—	—	—	11	—
5 th - Rm # 515	0	—	—	—	—	10	—
4 th - Rm # 415	0	—	—	—	—	11	—
4 th - Rm # 409	0	—	—	—	—	9	—
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments:

The assessed location(s) (✓) Does () Does not meet established indoor air quality guidelines.

Signature: 

Date: 2/20/02

ATC ASSOCIATES, INC.

Page 13 of 14

TIME 17:35

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE DATE 2/20/02 PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
4 th - Rm 403	0	—	—	—	—	11	—
4 th - Rm 404	0	—	—	—	—	9	—
3 rd - Rm 306	0	—	—	—	—	10	—
3 rd - Rm 305	0	—	—	—	—	9	—
3 rd - Rm 309	0	—	—	—	—	7	—
3 rd - Rm 315	0	—	—	—	—	9	—
2 nd - Rm 202	0	—	—	—	—	8	—
2 nd - Rm 206	0	—	—	—	—	8	—
2 nd - Hallway	0	—	—	—	—	10	—
2 nd - Stairs B	0	—	—	—	—	9	—
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 2/20/02

CITY_21MC100_003058994

ATC ASSOCIATES, INC.

Page 14 of 14

TIME 17:55

INDOOR AIR QUALITY FIELD REPORT

(14894)

LOCATION H.S. FOR LEADERSHIP & PUBLIC SERVICE

DATE 2/20/02

PROJECT NO. 19125-0290

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
1 st - rm 123	-	-	-	-	-	12	-
1 st - ^{center of} vestibule	-	-	-	-	-	11	-
1 st - Stairs A	-	-	-	-	-	9	-
BSMT - #B06	-	-	-	-	-	10	-
BSMT - #B19	-	-	-	-	-	11	-
BSMT - rm B23	-	-	-	-	-	10	-
BSMT - hallway	-	-	-	-	-	12	-
by entrance	-	-	-	-	-	44	-
out of building	-	-	-	-	-	52	-
North	-	-	-	-	-	66	-
out of Bldg.	-	-	-	-	-		-
South	-	-	-	-	-		-
out of Building	-	-	-	-	-		-
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does (X) Does not meet established indoor air quality guidelines.

Signature: _____

Date: 2/20/02

CITY_21MC100_003058995