NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: H.S. for Leadership & Public Service
90 Trinity Place, NY, NY

Received: 4/13/02 5:00:00 PM
ATC Group #: 7403
Analysis Date: 4/13/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
04 *7403 -1*	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 *7403 -2*	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 *7403 -3*	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 *7403 -4*	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 *7403 -5*	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 *7403 -6*	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 *7403 -7*	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV
Analyzed by: RRy

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003060180

NYC-WTC_000204365

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: H.S. for Leadership & Public Service
90 Trinity Place, NY, NY

Received: 4/13/02 5:00:00 PM
ATC Group #: 7403
Analysis Date: 4/13/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
11 *7403 -8*	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
12 *7403 -9*	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 *7403 -10*	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 *7403 -11*	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 *7403 -12*	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 *7403 -13*	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
17 *7403 -14*	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 *7403 -15*	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
19 *7403 -16*	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003060181

NYC-WTC_000204366

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: H.S. for Leadership & Public Service
90 Trinity Place, NY, NY

Received: 4/13/02 5:00:00 PM
ATC Group #: 7403
Analysis Date: 4/13/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
20 *7403 -17*	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
21 *7403 -18*	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003060182

NYC-WTC_000204367