

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 12

TIME 2:00

LOCATION Stuyvesant H.S. (M477) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                        | Occup. | Temperature (°F)                 | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | VOCs (ppm) |
|---------------------------------|--------|----------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|------------|
| Outside                         |        | 83.8                             | 78.9                  | 402                        | 1                     | 54                                           | 0          |
| 1st floor Hallway, North        | 15     | 70.1                             | 52.5                  | 689                        | 1                     | 32                                           | 0          |
| Auditorium                      | 5      | 71.6                             | 55.8                  | 690                        | 0                     | 34                                           | 0          |
| 1st fl. lobby                   | 20     | 70.5                             | 53.6                  | 705                        | 1                     | 30                                           | 0          |
| 125                             | 10     | 72.3                             | 55.4                  | 740                        | 0                     | 31                                           | 0          |
| 129                             | 3      | 72.6                             | 53.2                  | 722                        | 0                     | 32                                           | 0          |
| 132                             |        | 72.4                             | 52.6                  | 689                        | 0                     | 30                                           | 0          |
| 133                             |        | 71.5                             | 53.4                  | 692                        | 0                     | 29                                           | 0          |
| Hallway by 133                  | 8      | 72.1                             | 52.8                  | 736                        | 0                     | 30                                           | 0          |
| Stair West side                 |        | 74.6                             | 55.9                  | 710                        | 1                     | 34                                           | 0          |
| Guideline levels ASHRAE/AIA/EPA |        | 68-75°F/winter<br>73-79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24 hour average      | 1 ppm      |

Comments:

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: H. Aubrey

Date: 6/24/02

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

TIME 8:30

LOCATION Stuyvesant H.S (MATH) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                            | Occup. | Temperature<br>(°F)              | Relative<br>Humidity (%) | Carbon Dioxide<br>(ppm)    | Carbon Monoxide<br>(ppm) | Respirable<br>Particulates (ug/m <sup>3</sup> ) | TVOCs<br>(ppm) |
|-------------------------------------|--------|----------------------------------|--------------------------|----------------------------|--------------------------|-------------------------------------------------|----------------|
| 2nd fl. lobby                       | 8      | 71.5                             | 55.1                     | 726                        | 0                        | 29                                              | 0              |
| 213 m. office                       |        | 72.4                             | 52.6                     | 710                        | 0                        | 28                                              | 0              |
| 211 G. office                       |        | 72.7                             | 53.8                     | 729                        | 0                        | 28                                              | 0              |
| 260                                 |        | 73.4                             | 54.5                     | 685                        | 0                        | 30                                              | 0              |
| 229                                 |        | 73.2                             | 54.2                     | 730                        | 0                        | 30                                              | 0              |
| 231                                 |        | 73.1                             | 54.1                     | 692                        | 0                        | 31                                              | 0              |
| 233                                 |        | 72.8                             | 55.8                     | 705                        | 0                        | 30                                              | 0              |
| 235                                 |        | 73.9                             | 56.1                     | 700                        | 0                        | 29                                              | 0              |
| 236 Gd. office                      |        | 73.0                             | 55.2                     | 715                        | 0                        | 28                                              | 0              |
| 237                                 |        | 73.5                             | 55.7                     | 685                        | 0                        | 30                                              | 0              |
| Guideline levels<br>ASHRAE/AIAA/EPA |        | 68-75°F/winter<br>73-79°F/summer | 30-60%                   | Outdoor level +<br>700 ppm | 9 ppm                    | 65 ug/m <sup>3</sup><br>24-hour average         | 1 ppm          |

Comments:

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: H. Holey

Date: 6/24/02

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 12TIME 8:55LOCATION Stuyvesant H.S. (M477) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                            | Occup. | Temperature<br>(°F)              | Relative<br>Humidity (%) | Carbon Dioxide<br>(ppm)    | Carbon Monoxide<br>(ppm) | Respirable<br>Particulates (ug/m <sup>3</sup> ) | TVOC's<br>(ppm) |
|-------------------------------------|--------|----------------------------------|--------------------------|----------------------------|--------------------------|-------------------------------------------------|-----------------|
| 3rd fl. Hallway                     | 5      | 72.4                             | 52.6                     | 511                        | 0                        | 29                                              | 0               |
| 3rd fl. Gym                         |        | 79.6                             | 67.9                     | 539                        | 1                        | 36                                              | 0               |
| 303                                 |        | 73.6                             | 53.4                     | 616                        | 1                        | 32                                              | 0               |
| 305                                 |        | 74.1                             | 54.0                     | 522                        | 0                        | 30                                              | 0               |
| 307                                 |        | 73.0                             | 52.5                     | 489                        | 1                        | 29                                              | 0               |
| 313                                 |        | 72.9                             | 53.2                     | 596                        | 0                        | 31                                              | 0               |
| 315                                 |        | 73.1                             | 54.1                     | 603                        | 0                        | 31                                              | 0               |
| 327                                 |        | 72.8                             | 53.0                     | 584                        | 0                        | 30                                              | 0               |
| 329                                 |        | 73.5                             | 55.2                     | 622                        | 0                        | 29                                              | 0               |
| 333                                 |        | 72.6                             | 54.8                     | 601                        | 0                        | 28                                              | 0               |
| Guideline levels<br>ASHRAE/AHIA/EPA |        | 68-75°F/winter<br>73-79°F/summer | 30-60%                   | Outdoor level +<br>700 ppm | 9 ppm                    | 65 ug/m <sup>3</sup><br>24-hour average         | 1 ppm           |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: *H. Anthony* Date: 6/24/02

CITY\_21MC100\_003060528

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 12

TIME 9:20

LOCATION Stuyvesant H.S. (M477) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                            | Occup. | Temperature (°F)                     | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|--------------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| 335                                 |        | 73.1                                 | 55.6                  | 520                        | 1                     | 30                                           | 0           |
| 336 Ph. office                      |        | 72.0                                 | 54.8                  | 548                        | 1                     | 34                                           | 0           |
| 337                                 |        | 73.0                                 | 56.9                  | 605                        | 1                     | 32                                           | 0           |
| 338 Ph. lab                         |        | 72.2                                 | 55.4                  | 567                        | 1                     | 35                                           | 0           |
| 339                                 |        | 73.4                                 | 56.2                  | 620                        | 0                     | 31                                           | 0           |
| 350                                 |        | 72.5                                 | 56.7                  | 533                        | 0                     | 31                                           | 0           |
| 351                                 |        | 73.3                                 | 56.9                  | 670                        | 0                     | 29                                           | 0           |
| 4th Fl Hallway                      |        | 72.9                                 | 53.4                  | 642                        | 1                     | 27                                           | 0           |
| 401                                 |        | 73.1                                 | 55.2                  | 585                        | 0                     | 29                                           | 0           |
| 402 office                          |        | 72.6                                 | 53.8                  | 611                        | 0                     | 28                                           | 0           |
| Guideline levels<br>ASHRAE/ATIA/EPA |        | 68 - 75°F/winter<br>73 - 79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments:

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: A. de Jong Date: 6/24/02

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 12

TIME 9:40

LOCATION Stuyvesant H.S (M477) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                            | Occup. | Temperature (°F)                   | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|------------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| 403                                 |        | 72.6                               | 56.2                  | 605                        | 0                     | 29                                           | 0           |
| 404                                 |        | 73.7                               | 55.8                  | 572                        | 1                     | 27                                           | 0           |
| 405                                 |        | 74.2                               | 56.4                  | 540                        | 0                     | 28                                           | 0           |
| 407                                 |        | 73.8                               | 56.6                  | 489                        | 0                     | 26                                           | 0           |
| 411                                 |        | 74.0                               | 55.9                  | 494                        | 1                     | 27                                           | 0           |
| 413                                 |        | 73.2                               | 56.3                  | 520                        | 1                     | 29                                           | 0           |
| 427                                 |        | 73.7                               | 56.7                  | 516                        | 1                     | 29                                           | 0           |
| 429                                 |        | 72.5                               | 57.0                  | 530                        | 0                     | 30                                           | 0           |
| 431                                 |        | 73.6                               | 57.3                  | 524                        | 0                     | 27                                           | 0           |
| 433                                 |        | 73.4                               | 56.8                  | 518                        | 1                     | 29                                           | 0           |
| Guideline levels<br>ASHRAE/AHIA/EPA |        | 68 -75°F/winter<br>73 -79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: H. Long Date: 6/24/02

CITY\_21MC100\_003060530

ATC ASSOCIATES, INC.

Page 6 of 12

TIME 10:05

## INDOOR AIR QUALITY FIELD REPORT

LOCATION Stuyvesant H.S (M477) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                            | Occup. | Temperature<br>(°F)                | Relative<br>Humidity (%) | Carbon Dioxide<br>(ppm)    | Carbon Monoxide<br>(ppm) | Respirable<br>Particulates (ug/m <sup>3</sup> ) | TVOCs<br>(ppm) |
|-------------------------------------|--------|------------------------------------|--------------------------|----------------------------|--------------------------|-------------------------------------------------|----------------|
| 435                                 |        | 73.4                               | 55.6                     | 610                        | 0                        | 27                                              | 0              |
| 436                                 |        | 72.8                               | 56.0                     | 622                        | 0                        | 27                                              | 0              |
| 437                                 |        | 72.9                               | 56.2                     | 594                        | 0                        | 26                                              | 0              |
| 439                                 |        | 73.2                               | 55.8                     | 573                        | 0                        | 28                                              | 0              |
| 440                                 |        | 72.9                               | 56.4                     | 607                        | 0                        | 29                                              | 0              |
| 5th Fl. Hallway                     |        | 72.6                               | 54.3                     | 713                        | 1                        | 27                                              | 0              |
| Cafeteria                           |        | 73.2                               | 55.8                     | 765                        | 1                        | 30                                              | 0              |
| 503                                 |        | 73.4                               | 56.1                     | 642                        | 0                        | 29                                              | 0              |
| 505                                 |        | 72.8                               | 57.0                     | 677                        | 1                        | 27                                              | 0              |
| 507                                 |        | 73.0                               | 57.2                     | 570                        | 0                        | 27                                              | 0              |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68 -75°F/winter<br>73 -79°F/summer | 30-60%                   | Outdoor level +<br>700 ppm | 9 ppm                    | 65 ug/m <sup>3</sup><br>24-hour average         | 1 ppm          |

Comments: \_\_\_\_\_

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: H. Andrey Date: 6/24/02

CITY\_21MC100\_003060531

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

TIME 10:30

LOCATION Stuyvesant H.S. (M4TH) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                            | Occup. | Temperature<br>(°F)              | Relative<br>Humidity (%) | Carbon Dioxide<br>(ppm)    | Carbon Monoxide<br>(ppm) | Respirable<br>Particulates (ug/m <sup>3</sup> ) | VOC's<br>(ppm) |
|-------------------------------------|--------|----------------------------------|--------------------------|----------------------------|--------------------------|-------------------------------------------------|----------------|
| 511                                 |        | 73.1                             | 57.6                     | 633                        | 0                        | 28                                              | 0              |
| 513                                 |        | 72.9                             | 58.0                     | 615                        | 0                        | 29                                              | 0              |
| 525                                 |        | 72.7                             | 57.9                     | 684                        | 1                        | 28                                              | 0              |
| 6th Fl. Hallway                     |        | 72.7                             | 56.4                     | 703                        | 1                        | 26                                              | 0              |
| 6th Fl. Gym                         |        | 73.4                             | 58.3                     | 745                        | 1                        | 29                                              | 0              |
| 601 office                          |        | 72.9                             | 57.2                     | 702                        | 0                        | 27                                              | 0              |
| 615 library                         |        | 73.0                             | 57.8                     | 767                        | 0                        | 26                                              | 0              |
| 627                                 |        | 73.2                             | 56.4                     | 644                        | 1                        | 27                                              | 0              |
| 629                                 |        | 73.0                             | 56.9                     | 628                        | 0                        | 26                                              | 0              |
| 635                                 |        | 73.5                             | 57.2                     | 610                        | 0                        | 26                                              | 0              |
| Guideline levels<br>ASHRAE/AHIA/EPA |        | 68-75°F/winter<br>73-79°F/summer | 30-60%                   | Outdoor level +<br>700 ppm | 9 ppm                    | 65 ug/m <sup>3</sup><br>24-hour average         | 1 ppm          |

Comments:

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: H. Anderson

Date: 6/24/02

ATC ASSOCIATES, INC.

Page 8 of 12TIME 10:55

## INDOOR AIR QUALITY FIELD REPORT

LOCATION Stuyvesant H.S (M477) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                            | Occup. | Temperature<br>(°F)              | Relative<br>Humidity (%) | Carbon Dioxide<br>(ppm)    | Carbon Monoxide<br>(ppm) | Respirable<br>Particulates (ug/m <sup>3</sup> ) | TVOCs<br>(ppm) |
|-------------------------------------|--------|----------------------------------|--------------------------|----------------------------|--------------------------|-------------------------------------------------|----------------|
| 636                                 |        | 72.6                             | 55.2                     | 605                        | 0                        | 21                                              | 0              |
| 638                                 |        | 73.1                             | 56.4                     | 594                        | 0                        | 28                                              | 0              |
| 639                                 |        | 73.0                             | 56.1                     | 612                        | 0                        | 28                                              | 0              |
| 640                                 |        | 72.9                             | 55.4                     | 623                        | 0                        | 26                                              | 0              |
| Stair West<br>side                  |        | 74.9                             | 55.0                     | 672                        | 0                        | 29                                              | 0              |
| 7th floor<br>Hallway                |        | 73.0                             | 53.2                     | 596                        | 0                        | 25                                              | 0              |
| 701 office                          |        | 73.6                             | 52.8                     | 486                        | 1                        | 24                                              | 0              |
| 702 office                          |        | 72.8                             | 53.6                     | 493                        | 1                        | 24                                              | 0              |
| 703 lab                             |        | 73.6                             | 55.2                     | 560                        | 1                        | 25                                              | 0              |
| 704 office                          |        | 72.9                             | 53.7                     | 511                        | 1                        | 24                                              | 0              |
| Guideline levels<br>ASHRAE/AIHA/EPA |        | 68-75°F/winter<br>73-79°F/summer | 30-60%                   | Outdoor level +<br>700 ppm | 9 ppm                    | 65 ug/m <sup>3</sup><br>24-hour average         | 1 ppm          |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: H. Arday Date: 6/24/02

CITY\_21MC100\_003060533

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 9 of 12

TIME 11:20

LOCATION Stuyvesant HS (M477) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                            | Occup. | Temperature<br>(°F)              | Relative<br>Humidity (%) | Carbon Dioxide<br>(ppm)    | Carbon Monoxide<br>(ppm) | Respirable<br>Particulates (ug/m <sup>3</sup> ) | TVOCs<br>(ppm) |
|-------------------------------------|--------|----------------------------------|--------------------------|----------------------------|--------------------------|-------------------------------------------------|----------------|
| 715                                 |        | 72.9                             | 56.3                     | 622                        | 0                        | 26                                              | 0              |
| 717                                 |        | 73.1                             | 55.6                     | 568                        | 1                        | 27                                              | 0              |
| 726 S.R                             |        | 74.2                             | 57.9                     | 942                        | 1                        | 29                                              | 0              |
| 727 lab                             |        | 74.3                             | 56.8                     | 605                        | 0                        | 28                                              | 0              |
| 736                                 |        | 73.6                             | 54.5                     | 512                        | 0                        | 25                                              | 0              |
| 737                                 |        | 72.8                             | 54.6                     | 678                        | 0                        | 26                                              | 0              |
| 738                                 |        | 72.6                             | 55.4                     | 711                        | 1                        | 25                                              | 0              |
| 739                                 |        | 73.1                             | 56.1                     | 640                        | 0                        | 27                                              | 0              |
| 740                                 |        | 73.0                             | 52.8                     | 621                        | 0                        | 26                                              | 0              |
| Stair West<br>side                  |        | 74.5                             | 56.8                     | 633                        | 1                        | 27                                              | 0              |
| Guideline levels<br>ASHRAE/AHIA/EPA |        | 68-75°F/winter<br>73-79°F/summer | 30-60%                   | Outdoor level +<br>700 ppm | 9 ppm                    | 65 ug/m <sup>3</sup><br>24-hour average         | 1 ppm          |

Comments:

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: H. A. Long Date: 6/24/02

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 10 of 12


TIME 11:45

LOCATION Stuyvesant H.S. (M477) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                            | Occup. | Temperature (°F)                 | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|----------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| <u>8th fl. Hallway</u>              |        | <u>72.6</u>                      | <u>53.6</u>           | <u>633</u>                 | <u>0</u>              | <u>25</u>                                    | <u>0</u>    |
| <u>801 office</u>                   |        | <u>73.3</u>                      | <u>54.1</u>           | <u>576</u>                 | <u>0</u>              | <u>26</u>                                    | <u>0</u>    |
| <u>807 F. lab</u>                   |        | <u>73.8</u>                      | <u>55.4</u>           | <u>585</u>                 | <u>1</u>              | <u>26</u>                                    | <u>0</u>    |
| <u>804</u>                          |        | <u>72.9</u>                      | <u>54.0</u>           | <u>641</u>                 | <u>0</u>              | <u>27</u>                                    | <u>0</u>    |
| <u>826 s. cl.</u>                   |        | <u>73.8</u>                      | <u>58.2</u>           | <u>985</u>                 | <u>1</u>              | <u>29</u>                                    | <u>0</u>    |
| <u>827 G. L.</u>                    |        | <u>73.9</u>                      | <u>55.6</u>           | <u>702</u>                 | <u>1</u>              | <u>28</u>                                    | <u>0</u>    |
| <u>835</u>                          |        | <u>72.8</u>                      | <u>54.7</u>           | <u>615</u>                 | <u>0</u>              | <u>26</u>                                    | <u>0</u>    |
| <u>836</u>                          |        | <u>73.4</u>                      | <u>53.5</u>           | <u>546</u>                 | <u>0</u>              | <u>26</u>                                    | <u>0</u>    |
| <u>840</u>                          |        | <u>73.0</u>                      | <u>54.6</u>           | <u>533</u>                 | <u>0</u>              | <u>25</u>                                    | <u>0</u>    |
| <u>Stair West side</u>              |        | <u>74.2</u>                      | <u>55.9</u>           | <u>528</u>                 | <u>0</u>              | <u>28</u>                                    | <u>0</u>    |
| Guideline levels<br>ASHRAE/AHIA/EPA |        | 68-75°F/winter<br>73-79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments: \_\_\_\_\_

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 6/24/02

CITY\_21MC100\_003060535

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 11 of 12

TIME 12:10

LOCATION Stuyvesant H.S. (M477) DATE 6/24/02 PROJECT NO. 1925-0246

| Location                            | Occup. | Temperature (°F)                   | Relative Humidity (%) | Carbon Dioxide (ppm)       | Carbon Monoxide (ppm) | Respirable Particulates (ug/m <sup>3</sup> ) | TVOCs (ppm) |
|-------------------------------------|--------|------------------------------------|-----------------------|----------------------------|-----------------------|----------------------------------------------|-------------|
| 9th H. Hallway                      |        | 72.8                               | 55.6                  | 665                        | 0                     | 28                                           | 0           |
| 901 office                          |        | 73.1                               | 56.3                  | 572                        | 0                     | 27                                           | 0           |
| 902                                 |        | 73.6                               | 54.5                  | 584                        | 0                     | 25                                           | 0           |
| 925 lab                             |        | 73.4                               | 56.2                  | 620                        | 1                     | 27                                           | 0           |
| 926 s. CA                           |        | 75.2                               | 58.4                  | 897                        | 1                     | 28                                           | 0           |
| 935                                 |        | 73.5                               | 57.3                  | 703                        | 1                     | 26                                           | 0           |
| 936                                 |        | 74.2                               | 54.5                  | 674                        | 0                     | 27                                           | 0           |
| 938 s. R.                           |        | 74.9                               | 57.4                  | 996                        | 1                     | 29                                           | 0           |
| 939                                 |        | 73.1                               | 56.3                  | 612                        | 1                     | 26                                           | 0           |
| 940                                 |        | 72.9                               | 55.8                  | 572                        | 1                     | 25                                           | 0           |
| Guideline levels<br>ASHRAE/AHIA/EPA |        | 68 -75°F/winter<br>73 -79°F/summer | 30-60%                | Outdoor level +<br>700 ppm | 9 ppm                 | 65 ug/m <sup>3</sup><br>24-hour average      | 1 ppm       |

Comments:

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature:

*[Signature]* Date: 6/24/02

ATC ASSOCIATES, INC.  
INDOOR AIR QUALITY FIELD REPORT

Page 12 of 12

TIME 12:35

LOCATION Stuyvesant H.S. (M477) DATE 6/24/02 PROJECT NO. 19125-0246

| Location                           | Occup. | Temperature<br>(°F)                | Relative<br>Humidity (%) | Carbon Dioxide<br>(ppm)    | Carbon Monoxide<br>(ppm) | Respirable<br>Particulates (ug/m <sup>3</sup> ) | TVOCs<br>(ppm) |
|------------------------------------|--------|------------------------------------|--------------------------|----------------------------|--------------------------|-------------------------------------------------|----------------|
| <u>10th St. Hallway</u>            |        | <u>72.5</u>                        | <u>53.6</u>              | <u>720</u>                 | <u>0</u>                 | <u>23</u>                                       | <u>0</u>       |
| <u>1001</u>                        |        | <u>73.1</u>                        | <u>54.9</u>              | <u>638</u>                 | <u>0</u>                 | <u>25</u>                                       | <u>0</u>       |
| <u>1004</u>                        |        | <u>72.9</u>                        | <u>55.2</u>              | <u>620</u>                 | <u>0</u>                 | <u>25</u>                                       | <u>0</u>       |
| <u>1006</u>                        |        | <u>73.5</u>                        | <u>53.6</u>              | <u>576</u>                 | <u>1</u>                 | <u>25</u>                                       | <u>0</u>       |
| <u>1007</u>                        |        | <u>73.7</u>                        | <u>52.8</u>              | <u>636</u>                 | <u>0</u>                 | <u>24</u>                                       | <u>0</u>       |
| <u>1009</u>                        |        | <u>72.8</u>                        | <u>53.7</u>              | <u>520</u>                 | <u>1</u>                 | <u>23</u>                                       | <u>0</u>       |
| <u>1010</u>                        |        | <u>73.1</u>                        | <u>54.8</u>              | <u>506</u>                 | <u>0</u>                 | <u>25</u>                                       | <u>0</u>       |
| <u>1017</u>                        |        | <u>73.6</u>                        | <u>54.0</u>              | <u>439</u>                 | <u>1</u>                 | <u>26</u>                                       | <u>0</u>       |
| <u>1024</u>                        |        | <u>73.5</u>                        | <u>54.3</u>              | <u>496</u>                 | <u>1</u>                 | <u>26</u>                                       | <u>0</u>       |
| <u>Outside</u>                     |        | <u>82.7</u>                        | <u>67.5</u>              | <u>403</u>                 | <u>1</u>                 | <u>43</u>                                       | <u>0</u>       |
| Guideline levels<br>ASHRAE/AIA/EPA |        | 68 -75°F/winter<br>73 -79°F/summer | 30-60%                   | Outdoor level +<br>700 ppm | 9 ppm                    | 65 ug/m <sup>3</sup><br>24-hour average         | 1 ppm          |

Comments:

The assessed location(s) ( ) Does ( ) Does not meet established indoor air quality guidelines.

Signature: A. G. Goy

Date: 6/24/02