

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 12TIME 8:00LOCATION Stuyvesant H.S. (M477) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Outside		56.4	25.7	438	1	20	0
1st floor Hallway, North	4	68.4	28.2	480	1	10	0
Auditorium		68.7	30.0	448	1	12	0
1st fl. lobby	8	68.3	30.4	501	1	7	0
125	30	69.8	33.4	896	0	10	0
129	30	70.3	34.1	944	0	12	0
132	1	70.6	30.0	603	0	14	0
133	30	72.4	32.6	975	0	11	0
Hallway by 133	4	71.2	30.2	571	1	10	0
Stair West side		72.6	29.4	421	1	9	0
Guideline levels ASHRAE/AHIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: H. A. Loz Date: 4/26/02

ATC ASSOCIATES, INC.

Page 2 of 12TIME 8:30

INDOOR AIR QUALITY FIELD REPORT

LOCATION Stuyvesant H.S (M477) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
<u>2nd fl. lobby</u>	<u>5</u>	<u>70.8</u>	<u>30.2</u>	<u>583</u>	<u>1</u>	<u>9</u>	<u>0</u>
<u>213 m. office</u>		<u>71.6</u>	<u>30.6</u>	<u>571</u>	<u>0</u>	<u>8</u>	<u>0</u>
<u>211 G. office</u>	<u>2</u>	<u>72.2</u>	<u>31.8</u>	<u>679</u>	<u>0</u>	<u>10</u>	<u>0</u>
<u>260</u>		<u>70.2</u>	<u>30.1</u>	<u>542</u>	<u>1</u>	<u>12</u>	<u>0</u>
<u>229</u>	<u>30</u>	<u>71.4</u>	<u>32.7</u>	<u>897</u>	<u>0</u>	<u>12</u>	<u>0</u>
<u>231</u>	<u>25</u>	<u>72.6</u>	<u>32.4</u>	<u>926</u>	<u>0</u>	<u>10</u>	<u>0</u>
<u>233</u>	<u>25</u>	<u>73.5</u>	<u>33.6</u>	<u>936</u>	<u>0</u>	<u>11</u>	<u>0</u>
<u>235</u>	<u>30</u>	<u>73.2</u>	<u>34.5</u>	<u>985</u>	<u>0</u>	<u>11</u>	<u>0</u>
<u>236 Gd. office</u>	<u>2</u>	<u>71.6</u>	<u>31.9</u>	<u>598</u>	<u>0</u>	<u>9</u>	<u>0</u>
<u>237</u>	<u>30</u>	<u>72.8</u>	<u>32.8</u>	<u>942</u>	<u>0</u>	<u>12</u>	<u>0</u>
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. A. Lopez Date: 4/26/02

ATC ASSOCIATES, INC.

Page 3 of 12TIME 8:55

INDOOR AIR QUALITY FIELD REPORT

LOCATION Stuyvesant H.S. (M477) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
<u>3rd fl. Hallway</u>	<u>3</u>	<u>72.4</u>	<u>30.4</u>	<u>528</u>	<u>1</u>	<u>9</u>	<u>0</u>
<u>3rd fl. Gym</u>	<u>20</u>	<u>72.2</u>	<u>32.6</u>	<u>896</u>	<u>1</u>	<u>14</u>	<u>0</u>
<u>303</u>	<u>30</u>	<u>73.7</u>	<u>30.9</u>	<u>1025</u>	<u>0</u>	<u>11</u>	<u>0</u>
<u>305</u>	<u>30</u>	<u>73.9</u>	<u>32.7</u>	<u>986</u>	<u>0</u>	<u>12</u>	<u>0</u>
<u>307</u>	<u>25</u>	<u>72.6</u>	<u>32.5</u>	<u>874</u>	<u>0</u>	<u>11</u>	<u>0</u>
<u>313</u>	<u>30</u>	<u>74.1</u>	<u>33.4</u>	<u>1008</u>	<u>0</u>	<u>13</u>	<u>0</u>
<u>315</u>	<u>30</u>	<u>71.5</u>	<u>33.6</u>	<u>1017</u>	<u>0</u>	<u>12</u>	<u>0</u>
<u>327</u>	<u>25</u>	<u>73.6</u>	<u>31.2</u>	<u>736</u>	<u>1</u>	<u>11</u>	<u>0</u>
<u>329</u>	<u>20</u>	<u>72.8</u>	<u>31.8</u>	<u>742</u>	<u>0</u>	<u>12</u>	<u>0</u>
<u>333</u>	<u>30</u>	<u>71.8</u>	<u>32.7</u>	<u>896</u>	<u>0</u>	<u>14</u>	<u>0</u>
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Adley Date: 4/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 62TIME 9:20LOCATION Stuyvesant H.S. (M477) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
335	20	72.6	31.4	895	0	12	0
336 Ph. office		69.7	28.6	675	0	14	0
337	25	70.8	32.7	876	0	13	0
338 Ph. lab		68.6	29.7	642	1	14	0
339	25	72.5	30.6	904	0	11	0
350		70.4	28.2	636	1	16	0
351		69.6	28.6	674	0	17	0
4th fl. Hallway	5	71.5	30.3	726	0	12	0
401	30	72.7	32.6	968	0	13	0
402 office		72.8	32.4	745	0	11	0
Guideline levels ASHRAE/AHIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: H. A. Long Date: 4/26/02

CITY_21MC100_003061248

ATC ASSOCIATES, INC.

Page 5 of 12TIME 9:40

INDOOR AIR QUALITY FIELD REPORT

LOCATION Stuyvesant H.S (M477) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
403	25	72.8	32.6	872	0	9	0
404	30	73.6	31.8	984	0	10	0
405		70.8	30.2	843	0	9	0
407		71.9	29.6	768	0	8	0
411	30	73.4	34.6	971	0	12	0
413	25	73.8	32.8	912	0	12	0
427		71.5	30.2	642	1	11	0
429	25	72.9	32.4	874	0	11	0
431		70.8	31.6	626	1	10	0
433	25	71.2	34.5	914	0	12	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 4/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 12TIME 10:05LOCATION Stuyvesant H.S (M477) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
435	1	72.8	29.7	705	0	12	0
436		73.2	28.6	664	0	10	0
437	5	72.7	30.2	685	0	11	0
439		73.0	29.6	682	0	14	0
440		71.6	28.4	744	0	12	0
5th fl. Hallway	20	72.8	30.4	826	1	11	0
Cafeteria	30	73.1	29.6	864	1	12	0
503		70.8	28.9	642	0	13	0
505	2	71.4	30.4	705	0	14	0
507	4	72.0	31.6	712	0	11	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. A. Day Date: 4/26/02

CITY_21MC100_003061250

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 12TIME 10:30LOCATION Stuyvesant H.S (MATH) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
511	25	72.6	32.6	872	0	12	0
513	20	70.8	32.8	848	0	14	0
525		71.2	30.1	576	0	10	0
6th fl. Hallway	6	72.8	30.6	672	0	9	0
6th fl. Gym		73.4	28.7	687	1	11	0
601 office		72.6	27.6	603	0	10	0
615 library	10	73.8	30.8	784	1	9	0
627		70.2	30.0	741	0	8	0
629	3	70.4	29.8	794	0	10	0
635		71.2	29.2	684	0	9	0
Guideline levels ASHRAE/AHIA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: H. Alay Date: 4/26/02

CITY_21MC100_003061251

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 12

TIME 10:50

LOCATION Stuyvesant H.S (M477) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
636	30	73.4	34.6	896	0	12	0
638		70.2	30.1	715	0	9	0
639	25	72.6	33.7	864	0	11	0
640	20	72.8	32.6	870	0	14	0
Stair West side		73.1	28.0	516	1	9	0
7th floor Hallway	6	72.9	29.7	744	0	8	0
701 office	1	73.1	29.9	712	0	10	0
702 office		72.9	30.0	706	0	9	0
703 lab		73.6	29.4	765	1	10	0
704 office		72.4	30.2	840	0	11	0
Guideline levels ASHRAE/AHHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: H. H. Long Date: 4/26/02

CITY_21MC100_003061252

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 9 of 12

TIME 11:15

LOCATION Stuyvesant HS (M47) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
715	10	72.6	30.6	742	0	12	0
717		70.3	28.8	657	0	10	0
726 S.R.	5	72.5	29.6	828	0	11	0
727 Lab		72.9	27.7	684	1	14	0
736		70.8	29.6	712	0	13	0
737	20	73.1	32.6	974	0	12	0
738	15	72.4	32.1	873	0	14	0
739		69.8	29.7	728	0	12	0
740	20	70.2	32.9	926	0	10	0
Stair West side		72.6	27.4	562	1	11	0
ASHRAE/AMH/EPA Guideline levels		68 - 75°F/winter	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. Andrey Date: 4/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 10 of 12

TIME 11:40

LOCATION Stuyvesant H.S. (M477) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
8th Fl. Hallway	4	72.3	29.1	674	0	9	0
801 office		73.1	28.8	745	0	8	0
807 F. lab		71.8	28.6	767	1	12	0
804	20	72.6	30.2	898	0	11	0
826 s. cl.	25	73.2	31.4	890	0	13	0
827 G.L.		71.8	28.1	672	0	12	0
835	25	74.1	32.4	942	0	14	0
836		71.6	27.6	676	0	11	0
840	20	72.8	31.9	898	0	12	0
Stair West side		71.7	26.8	672	1	9	0
Guideline levels ASHRAE/AIA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. H. H.

Date: 4/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 11 of 12

TIME 12:00

LOCATION Stuyvesant H.S. (M477) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
<u>9th Fl. Hallway</u>	<u>6</u>	<u>72.8</u>	<u>29.6</u>	<u>728</u>	<u>0</u>	<u>9</u>	<u>0</u>
<u>901 office</u>		<u>73.1</u>	<u>28.7</u>	<u>762</u>	<u>0</u>	<u>10</u>	<u>0</u>
<u>902</u>	<u>20</u>	<u>70.7</u>	<u>31.7</u>	<u>897</u>	<u>0</u>	<u>11</u>	<u>0</u>
<u>925 lab</u>		<u>72.4</u>	<u>28.6</u>	<u>745</u>	<u>1</u>	<u>15</u>	<u>0</u>
<u>926 s. C</u>	<u>4</u>	<u>73.1</u>	<u>29.5</u>	<u>841</u>	<u>0</u>	<u>12</u>	<u>0</u>
<u>935</u>	<u>25</u>	<u>72.6</u>	<u>31.7</u>	<u>936</u>	<u>1</u>	<u>13</u>	<u>0</u>
<u>936</u>		<u>73.4</u>	<u>28.6</u>	<u>830</u>	<u>0</u>	<u>10</u>	<u>0</u>
<u>938 s. R.</u>	<u>10</u>	<u>72.5</u>	<u>32.7</u>	<u>905</u>	<u>0</u>	<u>12</u>	<u>0</u>
<u>939</u>	<u>30</u>	<u>73.2</u>	<u>33.8</u>	<u>895</u>	<u>0</u>	<u>13</u>	<u>0</u>
<u>940</u>	<u>25</u>	<u>73.6</u>	<u>32.8</u>	<u>912</u>	<u>1</u>	<u>14</u>	<u>0</u>
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

H. Arday Date: 4/26/02

CITY_21MC100_003061255

ATC ASSOCIATES, INC.

Page 12 of 12TIME 12:25

INDOOR AIR QUALITY FIELD REPORT

LOCATION Stuyvesant H.S. (M477) DATE 4/26/02 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
<u>10th Fl. Hallway</u>	<u>8</u>	<u>73.6</u>	<u>29.4</u>	<u>745</u>	<u>0</u>	<u>11</u>	<u>0</u>
<u>1001</u>	<u>30</u>	<u>73.8</u>	<u>34.6</u>	<u>976</u>	<u>0</u>	<u>12</u>	<u>0</u>
<u>1004</u>	<u>30</u>	<u>73.7</u>	<u>33.8</u>	<u>1020</u>	<u>0</u>	<u>12</u>	<u>0</u>
<u>1006</u>	<u>25</u>	<u>72.8</u>	<u>34.4</u>	<u>1005</u>	<u>0</u>	<u>14</u>	<u>0</u>
<u>1007</u>	<u>25</u>	<u>73.4</u>	<u>34.2</u>	<u>996</u>	<u>0</u>	<u>13</u>	<u>0</u>
<u>1009</u>	<u>20</u>	<u>72.5</u>	<u>33.8</u>	<u>897</u>	<u>0</u>	<u>13</u>	<u>0</u>
<u>1010</u>	<u>15</u>	<u>72.7</u>	<u>32.7</u>	<u>842</u>	<u>0</u>	<u>15</u>	<u>0</u>
<u>1017</u>	<u>20</u>	<u>73.1</u>	<u>33.8</u>	<u>875</u>	<u>1</u>	<u>12</u>	<u>0</u>
<u>1024</u>	<u>7</u>	<u>72.7</u>	<u>29.6</u>	<u>740</u>	<u>1</u>	<u>12</u>	<u>0</u>
<u>Outside</u>		<u>56.1</u>	<u>26.7</u>	<u>372</u>	<u>1</u>	<u>18</u>	<u>0</u>
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: H. A. Day Date: 4/26/02

CITY_21MC100_003061256