

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 04-29-02

CLIENT: NYC BOE

PROJECT ADDRESS: M477/345 Chambers Street
New York, NY 10007

PROJECT NO: 15125-0246

SAMPLED BY: C. Mathew

SAMPLE DATE: 04-27-02

DATE RECEIVED: 04-27-02

DATE ANALYZED: 04-27-02

SAMPLE MEDIA: Dust Wipe Sample

ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION (µg/ft²)	DETECTION LIMIT (µg/ft²)
11	9786	MER HVAC - 2 Supply Louver	174.7	15.7
12	9786	MER HVAC - 2 Supply Louver	38.2	19.2
13	9786	MER HVAC - 2 Return Louver	204.7	8.8
14	9786	MER HVAC - 1 Supply Louver	31.3	11.8
15	9786	MER HVAC - 1 Supply Liner	101.4	24.8
16	9786	MER HVAC 1 Return Louver	253.0	13.5
17	9786	MER HVAC 1 Return Liner	139.9	47.1
18	9786	MER HVAC 13 Return Left Liner	28.7	9.4
19	9786	MER HVAC 8 Return Left Liner	26.2	9.0
20	9786	MER HVAC 8 Supply Wall 1 Liner	36.7	21.6
21	9786	MER HVAC 9 Return Wall 1 Liner	27.3	9.0
22	9786	MER HVAC 9 Supply Wall 1 Liner	<9.0	9.0
23	9786	MER HVAC 7 Return Wall 1 Liner	48.8	18.0
24	9786	MER HVAC 7 Supply Wall 1 Liner	17.0	9.0

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

25	9786	HVAC 14 Supply Line Floor	200.5	9.0
28	9786	Blank	<9.0 µg	9.0 µg
29	9786	Blank	<9.0 µg	9.0 µg

NOTE 1:

THE REPORTING LIMIT (RL) IS 18.0 µg

NOTE 2:HUD Guidelines for final clearance dust wipe samples: Floor 40 µg/ft², Window sills 250 µg/ft²,
Window wells 400 µg/ft², Exterior surfaces 800 µg/ft².**NOTE 3:**

Blank units are in µg

CERTIFICATION AND SIGNATURESANALYSIS PERFORMED BY: TCUREPORT PREPARED BY: Juan

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: untLABORATORY DIRECTOR: Mil

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).