

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Akin A Cole

Cole Consulting Corp.

2269 Saw Mill River Road

Elmsford

NY 10523

Fax: (914) 345-0045

Phone: (914) 345-6000

Project: FDNY, Battalion 17

1080 Ogden Avenue, Bronx

Received: 5/10/02

8:00:00 PM

ATC Group #: 7703

Analysis Date: 5/11/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5μ-5 μ	5μ		(S/mm ²)	(S/cc)	
1 7703 -1	450.00	0.1124	0	None Detected	0	0	0.0076	<8.90	<0.0076	Fiber glass - None Detected Silicon - None Detected

Truck # SP 9706

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

7703

11

914-345-6000

2.5.4. INCOMPATIBILITY

89031

FDNY

SITE 1080 OGDEN AV. BRONX

TECHNICIAN

S. K. Adediji

DATE 5/10/02

SIGNATURE

8/11/2020

PROJECT #

CONTACT PHONE

914 345 6000

BLDG. NOS.

March 11, E 1891

ROTOMETER#

CASSETTE TYPE: 25mm 30mm POLYCARBONATE

ANALYSIS REQUESTED: PC1416 TSM

Daily Activity:

Test Performed : Pre : Du : Pz :

P = Pass F = Fail

ANALYZED BY:

DATE ANALYZED:

COMMENTS:

SENT TO	DATE	TIME	# OF SAMPLES	RECEIVED BY	DATE	TIME
ATC	5/17/02	20:00	1			
M. G. 1						