

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: John Anuforo
 Cole Consulting Corp.
 2269 Saw Mill River Road
 Elmsford NY 10523

Received: 6/3/02 9:30:00 AM
 ATC Group #: 7946
 Analysis Date: 6/3/02

Fax: (914) 345-0045 Phone: (914) 345-6000

Project: BAT #31
 N. Portland Avenue, Brooklyn, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5 µ	5µ		(S/mm ²)	(S/cc)	
1 7946 -1 # 216	450.00	0.1124	0	None Detected	0	0	0.0076	<8.90	<0.0076	Fiber Glass - None Detected Silicon - None Detected
2 7946 -2 an # 460	450.00	0.1124	0	None Detected	0	0	0.0076	<8.90	<0.0076	Fiber Glass - None Detected Silicon - None Detected
3 7946 -3 chide # 184	450.00	0.1124	0	None Detected	0	0	0.0076	<8.90	<0.0076	Fiber Glass - None Detected Silicon - None Detected

ROMAN PEYSAKHOV

Analyzed by: *RRV*

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

CITY_21MC100_010222125