

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: John Anuforo
 Cole Consulting Corp.
 2269 Saw Mill River Road
 Elmsford NY 10523

Received: 7/9/02 6:40:00 PM
 ATC Group #: 8427
 Analysis Date: 7/10/02

Fax: (914) 345-0045 Phone: (914) 345-6000

Project: FDNY
 234 East 29 Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
1 8427 -1	450.00	0.1124	0	None Detected	0	0	0.0076	<8.90	<0.0076	Fiber Glass - None Detected Silicon - None Detected

Ladder # 7

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

ENVIRONMENTAL TECHNOLOGIES
2269 Saw Mill River Road - Bldg. 5
Elmsford, NY 10523
914-345-6000

AIR SAMPLE COLLECTION
& CHAIN OF CUSTODY

SITE 234, E 29 St. Manhattan TECHNICIAN S. K. Adair
DATE 7/9/02 SIGNATURE [Signature]
PROJECT # EDN-7 CONTACT/PHONE 914 345 6000

ROTOMETER# _____

CASSETTE TYPE: 25mm, 37mm POLYCARBONATE

ANALYSIS REQUESTED: PCM (TEM)

Daily Activity: TEM TES

Test Performed: Pre x Dur x Post

P=Pass F=Fail

SAMPLE#	LOCATION	TIME START	TIME STOP	TOTAL MIN	FLOW RATE INIT/FINAL	VOL LITERS	FIBERS PER CC	P/F
1	INSIDE LADDER 7	1320	1450	90	515	450		
					11			
					1			
					1			
					1			
					1			
					1			
					1			
					1			
					1			
					1			
					1			
					1			
					1			
					1			

ANALYZED BY: _____

DATE ANALYZED: _____

COMMENTS:

IMMEDIATE TAT

SENT TO	DATE	TIME	# OF SAMPLES	RECEIVED BY	DATE	TIME
ATC LAB	7/9/02		1	ATC Lab / [Signature]	07/09/02	1840