

PAGE 02/31

KAM CONSULTANTS

KAM CONSULTANTS
35-40 36th Street
Long Island City
New York, 11106
Tel: (718) 729-1997
Fax: (718) 729-1876

**ANALYTICAL REPORT**

(Asbestos, Fiberglass and Silica in Air by TEM/EDXA AHERA Method)

Client: NEW YORK CITY FIRE DEPARTMENT
9 Metrotech Center
Brooklyn, NY 11201-3857

Project: FDNY Garage - 59 Poridge Avenue, Brooklyn, NY
Project # : E.C. #58
Date Sampled: 08/27/02
Date Received: 08/27/02
Date Analyzed: 08/28/02
Date Reported: 08/28/02

KAM Lab ID#: T020827C

Sample ID	Description/ Location	Air Volume (l)	Analytical Sensitivity particulate/cc	Airborne Concentration, particulate/cc*		
				Asbestos	Fiber Glass	Silica
T020827C-01	Inside Cabin Engine Co. #58	300	0.0049	<0.0049	<0.0049	<0.0049

* Concentration will be reported as less than (<) the analytical sensitivity if no particulates are detected.

Analyst:

A.B.
Alex Barengolts

Lab Manager:

David Chen
David Chen

NYS-DOH ELAP #: 11273

ATHA#: 100269

NIST-NV LAP#: 102047