NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017
Fax: (212) 922-0630 **Phone:** (212) 922-007
Project: NYC DDC American Express Bldg., 30th Floor
Vesey Street, NY, NY.

Received: 11/25/01 9:00:00 AM
ATC Group #: 5973
Analysis Date: 11/25/01

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*Structures* 0.5µ-5	5µ	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration* (S/mm²)	(S/cc)	*Notes*
115 5973 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
116 5973 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
117 5973 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
118 5973 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
119 5973 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
120 5973 -6	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	

ROMAN PEYSAKHOV
Analyzed by: RRey

MICHAEL A. GORYCKI, PH.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0; NY State ELAP #10879

NYC-WTC_000205180