

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8

Time: 8:00 AM LOCATION: PS 89

DATE: 5/31/02 PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
OUTSIDE							
SOUTH EXIT	0	70.1	65.6	512	2	53	0
PLAY GROUND N	20	70.1	65.6	512	2	53	0
PLAY GROUND S	0	70.1	65.6	512	2	53	0
SE CORNER	3	70.1	65.6	512	2	53	0
EAST SIDE	0	70.1	65.6	516	2	53	0
N/W CORNER	0	70.1	65.6	514	2	53	0
NORTH EXIT	0	70.1	65.6	515	2	53	0
SAN CORNER	0	70.1	65.6	515	2	53	0
NEXT TO AIR INTAKE	0	70.1	65.6	515	2	53	0
NORTH CORNER	0	70.1	65.6	515	2	53	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: 

Date: 5/31/02

06/03/2002 13:22 FAX 212 353 8308

ATC

007

CITY_21MC100_009261522

NYC-WTC_000205284

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8

Time: 8:30 AM LOCATION: PS 89

DATE: 5/31/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
HALLWAY NEXT TO CAFETERIA	30	75.7	49.1	796	2	20	0
NORTH EXIT	0	75.8	48.6	809	2	19	0
DANCE ROOM	1	75.6	48.7	782	2	10	0
CAFETERIA	16	72.6	47.3	743	2	11	0
HALLWAY BY RM 126	6	75.7	49.1	826	2	9	0
132 A	1	71.3	46.1	721	2	9	0
132 B	2	71.6	46.5	749	2	16	0
132 C	0	71.7	46.3	801	2	17	0
132 D	0	71.8	46.1	698	2	10	0
SOUTH EXIT	0	72.8	45.7	703	2	10	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/31/02

CITY_21MC100_009261523

NYC-WTC_000205285

06/03/2002 13:23 FAX 212 353 8308

ATC

008

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 8

Time: 9:00 AM

LOCATION:

PS 89

DATE: 5/31/02

PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
308	2	73.9	48.1	788	2	10	0
310	4	73.1	46.8	786	2	10	0
314 HALL	1	73.7	48.0	762	2	16	0
316	0	73.6	49.4	778	2	18	0
HALLWAY BY STAIR #2	1	73.8	48.1	799	2	10	0
326	0	73.9	49.9	872	2	8	0
328	0	73.9	52.4	692	2	6	0
330	20	74.4	52.7	769	2	14	0
314	0	73.3	47.7	757	2	14	0
332	15	74.6	51.4	930	2	16	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/31/02

CITY_21MC100_009261524

NYC-WTC_000205286

06/03/2002 13:23 FAX 212 353 8306

ATC

009

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 10

Time: 9:30 AM LOCATION: PS 89

DATE: 5/31/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
301	12	72.1	47.1	813	2	16	0
301 Hallway	1	73.1	46.3	878	2	20	0
302	15	75.5	54.7	1019	2	18	0
Hallway next to North Elevator Bank	0	73.3	50.6	1059	2	16	0
304	0	73.4	50.1	1026	2	14	0
Hallway next to South Elevator Bank	0	74.3	48.7	804	2	11	0
306	10	74.2	51.2	881	2	11	0
308 Hallway	0	74.3	48.6	791	2	16	0
315 Hallway	1	74.6	48.7	792	2	12	0
315 Gym	26	73.2	47.3	802	2	10	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/31/02

CITY_21MC100_009261525

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8

Time: 9:40 AM LOCATION: PS 89 M

DATE: 5/31/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
430	6	73.7	51.5	891	2	16	0
428 HALLWAY	3	73.8	51.6	944	2	2	0
426	20	74.1	51.8	1240	2	16	0
HALLWAY BY STAIR #2	1	73.8	51.2	910	2	10	0
410 HALLWAY	0	73.8	51.1	877	2	8	0
408 HALLWAY	0	73.8	50.8	876	2	8	0
NEXT TO ELEVATOR BANK	0	73.9	49.2	830	2	11	0
404	2	74.3	49.1	928	2	11	0
401 HALLWAY	0	73.9	52.2	841	2	12	0
402	1	74.2	49.5	1239	2	16	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/31/02

CITY_21MC100_009261526

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 10

Time: 10:00 AM LOCATION: PS 89

DATE: 5/31/02 PROJECT NO:

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
NEXT TO STAIR #2 HALLWAY 5TH FL	0	72.6	55.3	977	2	15	0
526	25	73.2	56.6	1498	2	11	0
528	0	73.6	57.3	991	2	12	0
517	2	73.9	59.9	749	2	16	0
550 HALLWAY	0	72.8	54.9	815	2	12	0
532	25	74.2	60.6	899	2	16	0
514	0	74.3	59.8	781	2	17	0
419	1	73.9	51.4	838	2	18	0
419 HALLWAY	0	73.2	50.7	878	2	10	0
432	20	73.6	52.5	945	2	11	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/31/02

06/03/2002 13:23 FAX 212 353 8308

ATC

012

CITY_21MC100_009261527

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8

Time: 10:00 AM LOCATION: PS 59

DATE: 5/31/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
NEXT TO STAIR #4	2	74.2	48.8	994	2	12	0
219	0	73.8	48.8	1159	2	16	0
232	14	73.9	48.9	1233	2	16	0
230	20	74.4	49.3	1086	2	10	0
217 HALLWAY	0	74.5	51.4	1054	2	11	0
228	0	74.2	48.9	999	2	16	0
226	10	74.2	48.7	947	2	11	0
AUDITORIUM	200	74.5	47.9	1105	2	10	0
204	25	74.6	50.6	1203	2	8	0
202	20	75.6	53.6	1154	2	13	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 5/31/02

CITY_21MC100_009261528

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8

Time: 10⁴⁰ AM LOCATION: PS 89

DATE: 5/31/02 PROJECT NO: _____

Location	Occupants	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
EASTSIDE OF ROOM 208	2	75.3	49.9	1121	2	11	0
EASTSIDE OF ROOM 201	20	75.4	49.9	1239	2	16	0
NEXT TO ELECTRICAL CLOSET 2ND FLOOR	0	75.4	49.0	1132	2	18	0
INSIDE Rm 206	0	75.6	49.1	1146	2	19	0
NEXT TO Rm 224	0	74.9	49.0	1261	2	11	0
NEXT TO SOUTH SIDE OF ROOM 217	0	74.3	49.0	1301	2	9	0
NEXT TO ROOM 217	3	74.6	49.8	1043	2	10	0
NEXT TO STAIRS #2 2ND FLOOR	0	74.3	49.3	1103	2	10	0
SOUTH END OF HALLWAY 2ND FLOOR	0	74.8	49.1	1026	2	18	0
NORTH END OF 2ND FLOOR HALLWAY	0	74.6	48.6	1088	2	14	0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73-79 °F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: [Signature]

Date: 5/31/02

CITY_21MC100_009261529

NYC-WTC_000205291

06/03/2002 13:24 FAX 212 353 8306
ATC
014