

Reports Health Misc. IH sampling



WTC INDUSTRIAL HYGIENE NOTICE

Date: 03/03/2002

To: Ray Master

CC: DDC- Bob Adams
LMIG- John Rabovsky
ATC- Mike Donovan
LMIG- IH File

From: Mike Ramsey

RE: Post-Abatement Clearance Sample Results

Ray,

Attached are the results of the post abatement clearance sampling performed at WTC 6, B5, duct bank removal. These samples were collected on 2/27/02. These were all area samples.

All results were below the limit of 0.01 fibers per cubic centimeter (f/cc), which is the standard used for buildings having general occupancy.

You should maintain these records as required by state, local, and federal requirements.

A handwritten signature in black ink, appearing to read "Mike Ramsey".

Michael D. Ramsey, CSP, CIH
Senior Industrial Hygienist

Enc. Post Abatement Clearance Sample Results (6 pages)