

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Received: 6/9/02 8:30:00 PM
ATC Group #: 8031
Analysis Date: 6/9/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP W & P File #: 1079-01-02
57 Ann Street, New York, NY.

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
03 8031 -1	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
04 8031 -2	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
05 8031 -3	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
06 8031 -4	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046
07 8031 -5	1500.00	0.0562	0	None Detected	0	0	0.0046	<17.79	<0.0046

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879