

310 Greenwich Street, Manhattan

Independence Plaza


Bulk Samples Not Collected: No suspicious materials found during inspections

TEM AIR TESTS: (200+ samples)

5 samples on each floor: 2nd floor through 39th floor,
32nd floor has one repeat sampling*
4 samples: 1st floor

* 10/19/01 32th floor (West Side corridor): 78.74 s/mm²

Mr. Victor Escalona of Commercial Laboratory Enterprise stated he advised client to HEPA vacuum the floors and wipe down the walls. On October 24, 2001, he repeated the sampling and the results were <19.69. Confirmation from building manager on actions taken is pending.



Debrah Dolan.
(212) 962-3530

310 Greenwich Street, Manhattan

Independence Plaza


Bulk Samples Not Collected: No suspicious materials found during inspections

TEM AIR TESTS: (200+ samples)

5 samples on each floor: 2nd floor through 39th floor,
32nd floor has one repeat sampling*
4 samples: 1st floor

* 10/19/01 32th floor (West Side corridor): 78.74 s/mm²

Mr. Victor Escalona of Commercial Laboratory Enterprise stated he advised client to HEPA vacuum the floors and wipe down the walls. On October 24, 2001, he repeated the sampling and the results were <19.69. Confirmation from building manager on actions taken is pending.

A handwritten signature in black ink, appearing to read "Victor Escalona", is written in a cursive style.