

SL Analytical, Inc.

208 Stonehinge Lane

Carle Place, NY 11514

Phone: (516) 997-7251 Fax: (516) 997-7528



Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, October 27, 2001

Ref Number: LI0116352

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5μ < 5μ	Non- Asbestos ≥ 5μ			(S/mm ²)	(S/cc)
304	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
305	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
306	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
307	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
308	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
309	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047

Earl Tracey

Analyst

Approved
Signatory

Disclaimer: This laboratory is not responsible for data reported in structures or tables that are not on online checked for accuracy by personnel. This laboratory is only responsible for data reported in structures or tables that are on-line checked for accuracy by personnel for EPA. This report must not be used to claim product endorsement by EPA, AP or any agency of the U.S. Government. This report renders only the findings stated above. Quality control data including 50% confidence limits and laboratory analytical accuracy and precision, available upon request.

© 1994 by John Wiley & Sons, Inc. All rights reserved. This journal is registered at the Copyright Clearance Center, Inc., 222 Rosewood Drive, Danvers, MA 01923. Organizations in the U.S. who are also registered with C.C.C. may therefore copy material (beyond the limits permitted by sections 107 and 108 of U.S. copyright law) subject to payment to C.C.C. of the per copy fee of \$05.00. This consent does not extend to multiple copying for promotional or commercial purposes. ISI Tear Sheet Service, 3501 Market Street, Philadelphia, PA 19104, USA, is authorized to supply single copies of separate articles for private use only. Organizations authorized by the Copyright Licensing Agency may also copy material subject to the usual conditions. For all other use, permission should be sought from John Wiley & Sons, Inc.

Analytical, Inc.

208 Stonchings Lane

Carle Place, NY 11514

Phone: (516) 997-7251

Fax: (516) 997-7251

EMSL

Attn.:

Commercial Lab Enterprise
270 Swinton Avenue
Bronx, NY 10465

Saturday, October 27, 2001

Ref Number: L10116352

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM)
Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample ID	Volume (liters)	Asbestos Type(s)	# STRUCTURES		Area Analyzed (mm ²)	Analytical Sensitivity (S/cc)	Asbestos Concentration	
			≥ 0.5µ - < 5µ	Non- Asbestos ≥ 5µ			(S/mm ²)	(S/cc)
298	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
299	1320.00	None Detected		0	0.0635	0.0046	<15.75	<0.0046
300	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
301	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
302	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047
303	1300.00	None Detected		0	0.0635	0.0047	<15.75	<0.0047

Earl Tracey

Analyst

Approved
Signature

Disclaimer: This laboratory is not responsible for data reported in structurespec which is dependent on volume analyzed by the laboratory. This laboratory is only responsible for data reported in structurespec. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NYS AHERA or any agency of the U.S. Government. The data is for the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

EMSL Analytical, Inc. 208 Stonchings Lane, Carle Place, NY 11514
 Phone: (516) 997-7251 Fax: (516) 997-7251